

Eventus Construction Company Inc.

Cemco Water & Wastewater Specialists Inc.

District: Carmel Central School District

Location: George Fischer Elementary School

KEY:

Type of Outlet:	WF= Water Fountain
NO= Nurse Office	KS= Kitchen Sink
FL= Faculty Lounge	CS= Classroom Sink
BO= Boiler Room	OS= Outside Spigot
RR= Restroom Sink	EW= Eye Wash
SS= Slop Sink	FS= Floor Spigot
E= Exceed Allowable Limit	

Draw:	
Date:	9/17/2017
Time:	8:18 AM- 11:10 AM

Sample ID	Location	Type of Outlet	Lead Concentration	Notes Required	E
GFMS- 001	Front D Wing	OS	0.003		
GFMS- 002	Front D Wing	OS	0.167		E
GFMS- 003	Front C Wing	OS		Does not work	
GFMS- 004	Front C Wing	OS		Does not work	
GFMS- 005	Back C Wing	OS		Does not work	
GFMS- 006	Back C Wing	OS	0.15		E
GFMS- 007	Back C Wing	OS	0.302		E
GFMS- 008	Back A Wing	OS		Does not work	
GFMS- 009	Back A Wing	OS		Does not work	
GFMS- 010	Front A Wing	OS		Does not work	
GFMS- 011	Front A Wing	OS		Does not work	
GFMS- 012	Front A Wing By Main Entrance	OS	0.061		E
GFMS- 013	Boiler Rm Slop Sink	BO	0.003		
GFMS- 014	Custodial Bathroom	RR	0.001		

GFMS- 015	Custodial Break Rm	FL	< 0.001		
GFMS- 016	Kitchen Sink	KS	0.005		
GFMS- 017	Kitchen Sink	KS	0.004		
GFMS- 018	Kitchen Fill for Cooker	KS	0.009		
GFMS- 019	Kitchen Sink	KS	0.002		
GFMS- 020	Kitchen Sink	KS	0.002		
GFMS- 021	Kitchen Sink	KS	0.006		
GFMS- 022	Kitchen Sink	KS	0.004	Leaking	
GFMS- 023	Kitchen Sink	KS	0.002		
GFMS- 024	Kitchen Bathroom Sink	RR	0.002		
GFMS- 025	Kitchen Slop Sink	LR	0.012		
GFMS- 026	Kitchen DW Hose	KS	0.002		
GFMS- 027	Band Room Sink	CS	0.005		
GFMS- 028	Orchestra Rm	CS	0.001		
GFMS- 029		WF		Does not work	
GFMS- 030	Shop Tech Rm	CS	0.004		
GFMS- 031	Shop Tech Rm	CS	0.006		
GFMS- 032	Shop Wood Rm	CS	0.002	Leaks	
GFMS- 033	Shop Wood Rm	CS	0.001		
GFMS- 034	Girls Gym Off. BR Sink	RR	0.032		E
GFMS- 035	Girls Gym Locker Rm BR Sink	RR	0.004		
GFMS- 036	Girls Gym Locker Rm BR Sink	RR	0.015		
GFMS- 037	Boys Gym Locker Rm BR Sink	RR	0.002		

GFMS- 038	Boys Gym Locker Rm BR Sink	RR	0.005		
GFMS- 039	Boys Gym Off. BR Sink	RR	0.008		
GFMS- 040	Basement Boys Gang BR Sink	RR	0.003		
GFMS- 041	Basement Boys Gang BR Sink	RR	0.002		
GFMS- 042	Basement Boys Gang BR Sink	RR	0.002		
GFMS- 043	Basement Slop Sink	JC	0.013		
GFMS- 044	Basement Hall WF(Short)	WF	< 0.001		
GFMS- 045	Basement Hall WF(Tall)	WF	< 0.001		
GFMS- 046	Basement Girls Gang BR Sink	RR	0.003		
GFMS- 047	Basement Girls Gang BR Sink	RR	0.003		
GFMS- 048	Basement Girls Gang BR Sink	RR	0.002		
GFMS- 049	Rm 117 Water Fountain	CS	0.001	Cloudy	
GFMS- 050	Rm 118 Sink	CS	0.007		
GFMS- 051		VOID			
GFMS- 052	1st Flr A Wing Mens BR Sink	RR	0.005		
GFMS- 053	1st Flr A Wing Mens BR Sink	RR	0.001		
GFMS- 054	1st Flr A Wing Womens BR sink	RR	0.001		
GFMS- 055	1st Flr A Wing Womens BR sink	RR	0.001		
GFMS- 056	Main Office Copy Rm Sink	KS	0.003		
GFMS- 057	Main Office Copy Rm Sink	KS	0.037	Unsteady Flow	E
GFMS- 058	Main Office Water Fountain	WF	0.001		
GFMS- 059	Main Office Principals BR	RR	0.008		
GFMS- 060	1st Flr A Wing Hall Handicap BR	RR	0.001		

GFMS- 061	Rm 102 Sink	CS	0.010		
GFMS- 062	Rm 102 Water Fountain	WF	0.001		
GFMS- 063	Rm 103 Sink	CS	0.005		
GFMS- 064	Rm 103 Water Fountain	WF	0.001	Cloudy	
GFMS- 065	Rm 104 Sink	CS	0.005		
GFMS- 066	Rm 104 Water Fountain	WF	0.001	Cloudy	
GFMS- 067	Rm 105 Sink	CS	0.016		E
GFMS- 068	Rm 105 Water Fountain	WF	0.003	Cloudy	
GFMS- 069	Rm 106 Sink	CS	0.007		
GFMS- 070	Rm 106 Water Fountain	WF	0.002		
GFMS- 071	Rm 107 Sink	CS	0.008		
GFMS- 072		VOID			
GFMS- 073	Rm 107 Water Fountain	WF	0.001		
GFMS- 074	Rm 108 Sink	CS	0.010	Slight drip	
GFMS- 075	Rm 108 Water Fountain	WF	0.001	Cloudy	
GFMS- 076	Rm 109 Sink	CS	0.009		
GFMS- 077	Rm 109 Water Fountain	WF	0.002		
GFMS- 078	Rm 110 Sink	CS	0.010		
GFMS- 079	Rm 110 Water Fountain	WF	0.002		
GFMS- 080	1st Flr A Wing Girls Gang BR Sink	RR	0.002		
GFMS- 081	1st Flr A Wing Girls Gang BR Sink	RR	0.012		
GFMS- 082	1st Flr A Wing Hall WF (Tall)	WF	<0.001		
GFMS- 083	1st Flr A Wing Hall WF (Short)	WF	0.001	Cloudy	

GFMS- 084	1st Flr A Wing Slop Sink	Floor sink	0.007		
GFMS- 085	1st Flr A Wing Boys Gang BR Sink	RR	0.007		
GFMS- 086	Rm 114 Sink	CS	0.018		E
GFMS- 087	Rm 114 Water Fountain	WF	0.002	Cloudy	
GFMS- 088	Rm 116 Sink	CS	0.004		
GFMS- 089	Rm 116 Water Fountain	WF	0.002		
GFMS- 090	Rm 117 Sink	CS	0.004		
GFMS- 091	Rm 268 Eye Wash	EW	0.043		E
GFMS- 092	Rm 268 Sink	CS	0.013		
GFMS- 093	Rm 268 Sink	CS	0.004		
GFMS- 094	Rm 268 Sink	CS	0.001		
GFMS- 095	Rm 267/268 Prep. Rm Sink	CS	0.01		
GFMS- 096	Rm 267 Eye Wash	EW	0.061		E
GFMS- 097	Rm 267 Sink	CS	0.028		E
GFMS- 098	Rm 267 Sink	CS	0.006		
GFMS- 099	Rm 267 Sink	CS	0.004		
GFMS- 100	Rm 262 Eye Wash	EW	0.051		E
GFMS- 101	Rm 262 Sink	CS	0.006		
GFMS- 102	Rm 262 Sink	CS	0.110		
GFMS- 103	Rm 262 Sink	CS	0.200		E
GFMS- 104	Rm 262 Sink	CS	0.022		E
GFMS- 105	Rm 262 Sink	CS	0.014		
GFMS- 106	Rm 261/262 Prep. Rm Sink	CS	0.001		

GFMS- 107	Rm 261 Eye Wash	EW	0.002		
GFMS- 108	Rm 261 Sink	CS	0.001		
GFMS- 109	Rm 261 Sink	CS	0.004		
GFMS- 110	2nd Flr Girls Gang BR	RR	0.009		
GFMS- 111	2nd Flr Girls Gang BR	RR	0.002		
GFMS- 112	2nd Flr Girls Gang BR	RR	0.002		
GFMS- 113	2nd Flr Water Fountain (Tall)	WF	< 0.001		
GFMS- 114	2nd Flr Water Fountain (Short)	WF	< 0.001		
GFMS- 115	2nd Flr Slop Sink	SS	0.001		
GFMS- 116	2nd Flr Boys Gang BR	RR	0.002		
GFMS- 117	2nd Flr Boys Gang BR	RR	0.003		
GFMS- 118	2nd Flr Boys Gang BR	RR	0.002		
GFMS- 119	Rm 245 Sink	CS	< 0.001		
GFMS- 120	Rm 245 Sink	CS	< 0.001		
GFMS- 121	Rm 245 Sink	CS	< 0.001		
GFMS- 122	Rm 245 Sink	CS	0.001		
GFMS- 123	Rm 243 Sink	CS	0.001		
GFMS- 124	Rm 236 Sink (Art)	CS	< 0.001		
GFMS- 125	Rm 236 Sink (Art)	CS	< 0.001		
GFMS- 126	Rm 234 Sink (Art)	CS	< 0.001		
GFMS- 127	Rm 234 Sink (Art)	CS	< 0.001		
GFMS- 128	Rm 232 Sink (Art)	CS	< 0.001		
GFMS- 129	Rm 232 Sink (Art)	CS	0.001		

GFMS- 130	2nd Flr A Wing Mens BR	BS	0.002		
GFMS- 131	2nd Flr A Wing Womens BR	RR	< 0.001		
GFMS- 132	2nd Flr A Wing Teachers Lounge	FL	< 0.001		
GFMS- 133	Rm 218 Sink	CS	< 0.001		
GFMS- 134	Rm 218 Water Fountain	WF	< 0.001		
GFMS- 135	2nd Flr A Wing Handicap	RR	0.016		E
GFMS- 136	Rm 216 Sink	RR	0.006		
GFMS- 137	Rm 216 Water Fountain	WF	0.004		
GFMS- 138	Rm 202 Sink	CS	0.003		
GFMS- 139	Rm 202 Water Fountain	WF	< 0.001		
GFMS- 140	Rm 214 Sink	CS	0.008		
GFMS- 141	Rm 214 Water Fountain	WF	0.004		
GFMS- 142	Rm 203 Sink	CS	0.014		
GFMS- 143	Rm 203 Water Fountain	WF	< 0.001		
GFMS- 144	2nd Flr A Wing Boys Gang BR	CS	0.008		
GFMS- 145	2nd Flr A Wing Boys Gang BR	CS	0.007		
GFMS- 146	2nd Flr A Wing Slop Sink Cold Wtr	SS	0.004		
GFMS- 147	2nd Flr A Wing Slop Sink	SS	0.008		
GFMS- 148	2nd Flr A Wing WF (Tall)	WF	< 0.001		
GFMS- 149	2nd Flr A Wing WF (Short)	WF	0.006		
GFMS- 150	Rm 204 Sink	CS	0.004		
GFMS- 151	Rm 204 Water Fountain	WF	< 0.001		
GFMS- 152	2nd Flr A Wing Girls Gang BR	RR	0.006		

GFMS- 153	2nd Flr A Wing Girls Gang BR	RR	0.006		
GFMS- 154	Rm 210 Sink	CS	0.003		
GFMS- 155	Rm 210 Water Fountain	WF	0.001		
GFMS- 156	Rm 205 Sink	CS	0.012		
GFMS- 157	Rm 205 Water Fountain	WF	< 0.001		
GFMS- 158	Rm 209 Sink	CS	0.003		
GFMS- 159	Rm 209 Water Fountain	WF	0.001		
GFMS- 160	Rm 206 Sink	CS	0.013		
GFMS- 161	Rm 206 Water Fountain	WF	< .001		
GFMS- 162	Rm 208 Sink	CS	0.025		E
GFMS- 163	Rm 208 Water Fountain	WF	0.002	Leaky	
GFMS- 164	Rm 207 Sink	CS	0.015		E
GFMS- 165	Rm 207 Water Fountain	WF	0.002		
GFMS- 166	Rm 282 Sink	CS	0.001		
GFMS- 167	Rm 282 Sink	CS		Does not work	
GFMS- 168	Rm 282 Sink	CS	0.002		
GFMS- 169	Rm 282 Sink	CS	0.007		
GFMS- 170	Rm 282 Eye Wash	EW	0.035		E
GFMS- 171	Rm 282 Sink	CS	0.008		
GFMS- 172	2nd Flr D Wing Slop Sink	DD	0.001		
GFMS- 173	Rm 282/286 Prep. Rm Sink	CS	0.004		
GFMS- 174	Rm 286 Eye Wash	EW	0.042		E
GFMS- 175	Rm 286 Sink	CS	0.007		

GFMS- 176	Rm 286 Sink	CS	0.003		
GFMS- 177	Rm 286 Sink	CS	0.003		
GFMS- 178	Rm 286 Sink	CS	0.002		
GFMS- 179	Rm 286 Sink	CS	< .001		
GFMS- 180	Rm 118 Water Fountain	CS	< .001	Cloudy	
GFMS- 181	Rm 160 Sink	CS	0.002		
GFMS- 182	Rm 160 Water Fountain	CS	< .001		
GFMS- 183	Rm 161 Sink	CS	< .001		
GFMS- 184	Rm 161 Water Fountain	CS	< .001		
GFMS- 185	Rm 185 Sink	CS	< .001		
GFMS- 186	1st Flr C Wing Teachers Lounge Sink	FL	< .001		
GFMS- 187	1st Flr C Wing Girls Gang BR	RR	0.001		
GFMS- 188	1st Flr C Wing Hall WF (Tall)	WF	< 0.001		
GFMS- 189	1st Flr C Wing Hall WF (Short)	WF	< 0.001		
GFMS- 190	1st Flr C Wing Slop Sink	FS	0.003		
GFMS- 191	1st Flr C Wing Boys Gang BR	RR	0.002		
GFMS- 192	1st Flr C Wing Water Fountain	WF	<.001		
GFMS- 193	1st Flr A Wing Boys Side Gym WF	WF	< 0.001		
GFMS- 194	Nurse's Examination Rm Sink	NO	< 0.001		
GFMS- 195	Nurse's Bath Rm Sink	NO	< 0.001		
GFMS- 196	Nurse's Bath Rm Eye Wash	NO	< 0.001		
GFMS- 197	1st Flr A Wing Girls BR Sink	RR	0.008		
GFMS- 198	1sr Flr A Wing Boys Gang BR Sink	RR	0.008		

GFMS- 199	1st Flr C Wing Girls Gang BR	RR	< 0.001		
GFMS- 200	1st Flr C Wings Girls Gang BR	RR	< 0.001		
GFMS- 201		FS		Does not work	
GFMS- 202	1st Flr C Wing Boys Gang BR	RR	0.001		
GFMS- 203	1st Flr C Wing Boys Gang BR	RR	0.001		
GFMS- 204	Library Office Sink	FL	< 0.001		
GFMS- 205	1st Flr D Wing Slop Sink	SS	0.110		
GFMS- 206	1st Flr D Wing Slop Sink	IS		Does not work	
GFMS- 207	Basement Boys BR Floor Spigot	IS	1.62		E
GFMS- 208	Basement Girls BR Floor Spigot	IS		Does not work	
GFMS- 209	Rm 234/Kiln Room	CS	< 0.001		
GFMS- 210		PS		Does not work	
GFMS- 211	Floor Spigot Not Found	FS	0.862		E

General Comments:

The following fixtures were not functional and were unable to be sampled:

003, 004, 005, 008,009,010,011,167,210,201

These fixtures were reported to Terrence on 9/16/16 when the functionality of the fixtures were tested.

Labels GFMS-051 and GFMA-072 were voided. There is no fixture with these labels and in turn, no sample was taken.