

**Eventus Construction Company Inc.**

**Cemco Water & Wastewater Specialists Inc.**

District: Carmel Central School District

Location: Kent Primary Elementary School

Recorded By: 1-119 - Eli

**KEY:**

Type of Outlet:	WF= Water Fountain
NO= Nurse Office	KS= Kitchen Sink
FL= Faculty Lounge	CS= Classroom Sink
BO= Boiler Room	OS= Outside Spigot
RR= Restroom Sink	EW= Eye Wash
SS= Slop Sink	FS= Floor Sink
IS= Indoor Spigot	DW= Dish Washer
E= Exceed Allowable Limit	

Draw:	
Date:	9/17/2016
Time:	7:53 AM - 11:14 AM

Sample ID	Location	Type of Outlet	Lead Concentration	Notes Required	E
KPES- 001	Outside Rm 196	OS	0.025		E
KPES- 002	Outside Rm 124	OS	0.085		E
KPES- 003	Kitchen	KS	0.006		
KPES- 004	Kitchen	KS	0.009		
KPES- 005	Kitchen	KS	0.013		
KPES- 006	Kitchen	KS	0.003		
KPES- 007	Kitchen	KS	0.040		E
KPES- 008	Cafetorium	WF	0.004		
KPES- 009	Men's Room	RR	0.003		
KPES- 010	Women's Room	RR	0.003		
KPES- 011	Girl's Bathroom 137	RR	0.004		

KPES- 012	Girl's Bathroom 137	RR	0.004		
KPES- 013	Girl's Bathroom 137	RR	0.004		
KPES- 014	Girl's Bathroom 137	RR	0.014		
KPES- 015		WF	0.142	Does not work	E
KPES- 016		WF	0.304	Does not work	E
KPES- 017	Boy's Bathroom 135	RR	0.005		
KPES- 018	Boy's Bathroom 135	RR	0.006		
KPES- 019	Boy's Bathroom 135	RR	0.004		
KPES- 020	Faculty Room	FL	0.002		
KPES- 021		RR	0.013		
KPES- 022	Main Office	FL	0.012		
KPES- 023	Classroom 109	CS	0.008		
KPES- 024	Classroom 109	WF	0.003		
KPES- 025	Classroom 109	RR	0.004		
KPES- 026	Classroom 111	CS	0.013		
KPES- 027	Classroom 111	WF	0.004		
KPES- 028	Classroom 111	RR	0.009		
KPES- 029	Classroom 130	CS	0.006		
KPES- 030	Classroom 130	WF	0.003		
KPES- 031	Classroom 130	RR	0.004		
KPES- 032	Classroom 113	CS	0.007		
KPES- 033	Classroom 113	WF	0.002		

KPES- 034	Classroom 113	RR	0.004		
KPES- 035	Classroom 128	CS	0.006		
KPES- 036	Classroom 128	WF	0.002		
KPES- 037	Classroom 128	RR	0.003		
KPES- 038	Classroom 116	CS	0.007		
KPES- 039	Classroom 116	WF	0.002		
KPES- 040	Classroom 116	RR	0.005		
KPES- 041	Classroom 126	CS	0.01		
KPES- 042	Classroom 126	WF	0.008		
KPES- 043	Classroom 126	RR	0.005		
KPES- 044	Classroom 118	CS	0.013		
KPES- 045	Classroom 118	WF	0.004		
KPES- 046	Classroom 118	RR	0.003		
KPES- 047	Classroom 124	CS	0.004		
KPES- 048	Classroom 124	WF	0.002		
KPES- 049	Classroom 124	RR	0.006		
KPES- 050	Rm 120 (Multipurpose)	CS	0.016		E
KPES- 051	Rm 120 (Multipurpose)	WF	0.005		
KPES- 052	Rm 120 (Multipurpose)	RR	0.007		
KPES- 053	Classroom 122	CS	0.007		
KPES- 054	Classroom 122	WF	0.004		
KPES- 055	Classroom 122	RR	0.005		

KPES- 056	Library	CS	0.012		
KPES- 057	Bathroom	RR	0.004		
KPES- 058	Nurse's Office	NO	0.005		
KPES- 059	Nurse's Office	NO	0.004		
KPES- 060	Computer Lab	RR	0.019		E
KPES- 61	Classroom 144	CS	0.005		
KPES- 62	Classroom 144	WF	0.002		
KPES- 63	Classroom 144	RR	0.003		
KPES- 64	Classroom 157	CS	0.01		
KPES- 65	Classroom 157	WF	0.004		
KPES- 66	Classroom 157	RR	0.003		
KPES- 67	Classroom 146	CS	0.008		
KPES- 68	Classroom 146	WF	0.007		
KPES- 69	Classroom 146	RR	0.004		
KPES- 70	Gym Office	OS	0.004		
KPES- 71	Classroom 200	CS	0.005		
KPES- 72	Classroom 200	WF	0.004		
KPES- 73	Classroom 200	RR	0.004		
KPES- 74	Classroom 198	CS	0.010		
KPES- 75	Classroom 198	WF	0.002		
KPES- 76	Classroom 198	RR	0.004		
KPES- 77	Classroom 196	CS	0.006		

KPES- 78	Classroom 196	WF	0.002		
KPES- 79	Classroom 196	RR	0.004		
KPES- 80	Custodial Office	SS	0.008		
KPES- 081		BO	0.002		
KPES- 082	Classroom 194	CS	0.004		
KPES- 083	Classroom 194	WF	0.001		
KPES- 084	Classroom 194	RR	0.007		
KPES- 085	Classroom 192	CS	0.005		
KPES- 086	Classroom 192	WD	0.002		
KPES- 087	Classroom 186	RR	0.005		
KPES- 088	Classroom 186	CS	0.002		
KPES- 089	Classroom 186	WF	0.003		
KPES- 090	Classroom 192	RR	0.004		
KPES- 091	Classroom 190	CS	0.005		
KPES- 092	Classroom 190	WF	0.003		
KPES- 093	Classroom 190	RR	0.002		
KPES- 094	Classroom 188	CS	0.006		
KPES- 095	Classroom 188	WF	0.002		
KPES- 096	Classroom 188	RR	0.020		E
KPES- 097	Custodial Office	SS	0.001		
KPES- 098	Classroom 132	CS	0.007		
KPES- 099	Classroom 132	WF	0.002		

KPES- 100	Classroom 132	RR	0.003		
KPES- 101	Kitchen	KS	0.076		E
KPES- 102	Kitchen	KS	0.075		E
KPES- 103	Kitchen	KS	0.065		E
KPES- 104	Custodial Office	IS	0.013		
KPES- 105	Custodial Office	IS	0.075		E
KPES- 106	Boiler Room	EW	0.014		
KPES- 107	Boiler Room	IS	0.064		E
KPES- 108	Boiler Room	IS	0.107	RPZ Backblow Preventer	E
KPES- 109	Outside Faculty Rm	IS	0.304		E
KPES- 110	Outside Rm 118	IS	0.304	Req. key	E
KPES- 111	Outside Principal's Off	IS	0.757	Req. key	E
KPES- 112		IS		Does not work	
KPES- 113	Custodial Office	IS	0.048		E
KPES- 114	Custodial Office	IS	3.860		E
KPES- 115	Custodial Office	IS	0.180	Line with ball valve	E
KPES- 116	Kitchen	DW	0.155		E
KPES- 117	Kitchen	DW	0.046		E
KPES- 118	Faculty Room	FL	0.004		
KPES- 119	Boiler Room	IS	0.074		E

***Cemco Water & Wastewater Specialists Inc.***

District: Carmel Central School District

Location: Kent Primary Elementary Elementary School

General Comments:

Fixture 112 could not be sampled. The handle is broken on the spicket. This was reported to the faculty member on site on 9/16/16 when the functionality of the fixtures were tested.

Fixture 015 and 016 do not work. We opened th valve underneath to draw the sample.