

Eventus Construction Company Inc.				KEY:	Type of Outlet:	WF=Water Fountain		
Cemco Water & Wastewater Specialists Inc.					NO= Nurse Office	KS= Kitchen Sink		
District:	Carmel Central School District				FL= Faculty Lounge	CS= Classroom Sink		
Location:	Carmel High School				BO= Boiler Room	OS= Outside Spigot		
					RR= Restroom Sink	EW= Eye Wash		
					SS= Slop Sink	FS=Floor Sink		
					IS= Indoor Spigot	DW=Dish Washer		
					E= Exceed Allowable Limit			
Draw:								
Date:	10/8/2016							
Time:	7:30 A.M. - 11:00 A.M.							
SAMPLE #		LOCATION		TYPE OF OUTLET	LEAD	NOTES	ALLOWABLE LIMIT	
CHS-1				OUTSIDE SPIGOT	0.0014	NEEDS SIGN		
CHS-2				OUTSIDE SPIGOT	1.35	NEEDS SIGN	E	
CHS-3				OUTSIDE SPIGOT	0.0431	NEEDS SIGN	E	
CHS-4		63 WING FACING PARKING LOT		OUTSIDE SPIGOT		NOT WORKING		
CHS-5		80 WING EXT. BOYS L.R.		OUTSIDE SPIGOT		NOT WORKING		
CHS-6		80 WING EXT. GIRLS L.R.		OUTSIDE SPIGOT	0.0071	NEEDS SIGN		
CHS-7		80 WING EXT. BOYS R.R.			0.0041			
CHS-8		80 WING EXT. GIRLS R.R.			0.005			
CHS-9		63 WING GARAGE		OUTSIDE SPIGOT		NOT WORKING		
CHS-10				OUTSIDE SPIGOT	0.468	NEEDS SIGN	E	
CHS-11				OUTSIDE SPIGOT	0.096	NEEDS SIGN	E	
CHS-12		METAL SHOP		CLASSROOM SINK	0.0068			
CHS-13		METAL SHOP		EYEWASH	0.0363	NEEDS SIGN	E	
CHS-14		WOOD SHOP		CLASSROOM SINK	0.004			
CHS-15		WOOD SHOP		EYEWASH	0.0068			
CHS-16		MUSIC ANNEX		OUTSIDE SPIGOT		NOT WORKING		
CHS-17		MUSIC ANNEX		WATER FOUNTAIN	0.001			
CHS-18		MUSIC ANNEX GIRLS R.R.		BATHROOM SINK	0.0021			
CHS-19		MUSIC ANNEX GIRLS R.R.		BATHROOM SINK	0.0014			
CHS-20		MUSIC ANNEX C.C.		SLOP SINK	0.0019			
CHS-21		MUSIC ANNEX BOYS R.R.		BATHROOM SINK	0.0042			
CHS-22		MUSIC ANNEX BOYS R.R.		BATHROOM SINK	0.0019			

CHS-23		ALTERNATIVE H.S. F.L.		KITCHEN SINK	0.0039			
CHS-24		MUSIC ANNEX M-3		CLASSROOM SINK	0.0095			
CHS-25		MUSIC ANNEX		OUTSIDE SPIGOT			NOT WORKING	
CHS-26		29 BOILER ROOM SINK		SLOP SINK	0.0085			
CHS-27		RM 120		CLASSROOM SINK	0.0034			
CHS-28		RM 120		CLASSROOM SINK	0.0015			
CHS-29		RM 119		CLASSROOM SINK	0.001			
CHS-30		RM 119		CLASSROOM SINK	0.001			
CHS-31		RM 119		CLASSROOM SINK	0.001			
CHS-32		RM 119		CLASSROOM SINK	0.001			
CHS-33		63 COURTYARD		OUTSIDE SPIGOT			NOT WORKING	
CHS-34		63 COURTYARD		OUTSIDE SPIGOT	0.0099		NEEDS SIGN	
CHS-35		07 WING 1ST FLR FAC.BATHROOM		BATHROOM SINK	0.001			
CHS-36		RM 105		CLASSROOM SINK	0.0217			E
CHS-37		RM 105		CLASSROOM SINK	0.0092			
CHS-38		RM 105		CLASSROOM SINK			VALVE OFF	
CHS-39		RM 105		CLASSROOM SINK			VALVE OFF	
CHS-40		RM 105		CLASSROOM SINK			VALVE OFF	
CHS-41		RM 105		CLASSROOM SINK	0.0135			
CHS-42		RM 105		CLASSROOM SINK	0.0064			
CHS-43		RM 105		CLASSROOM SINK	0.0065			
CHS-44		RM 105		CLASSROOM SINK	0.0108			
CHS-45		RM 105		CLASSROOM SINK			VALVE OFF	
CHS-46		RM 105		CLASSROOM SINK			VALVE OFF	
CHS-47		RM 105		CLASSROOM SINK			VALVE OFF	
CHS-48		RM 105		CLASSROOM SINK	0.0014			
CHS-49		RM 105		EYEWASH	0.261		NEEDS SIGN	E
CHS-50		PREP ROOM		CLASSROOM SINK	0.0019			
CHS-51		RM 104		CLASSROOM SINK	0.0038			
CHS-52		RM 104		CLASSROOM SINK	0.0024			
CHS-53		RM 104		CLASSROOM SINK	0.0079			
CHS-54		RM 104		CLASSROOM SINK	0.0098			
CHS-55		RM 104		CLASSROOM SINK	0.0032			
CHS-56		RM 104		CLASSROOM SINK	0.0044			
CHS-57		RM 104		CLASSROOM SINK	0.0062			
CHS-58		RM 104		CLASSROOM SINK	0.002			
CHS-59		RM 104		CLASSROOM SINK	0.0041			
CHS-60		RM 104		CLASSROOM SINK	0.0034			

CHS-61		RM 104		CLASSROOM SINK	0.0064			
CHS-62		RM 104		CLASSROOM SINK	0.0048			
CHS-63		RM 104		CLASSROOM SINK	0.001			
CHS-64		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-65		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-66		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-67		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-68		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-69		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-70		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-71		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-72		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-73		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-74		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-75		RM 103		CLASSROOM SINK		VALVE OFF		
CHS-76		RM 103		CLASSROOM SINK	0.001			
CHS-77		PREP ROOM		CLASSROOM SINK	0.001			
CHS-78		RM 102		CLASSROOM SINK	0.001			
CHS-79		RM 102		EYEWASH	0.0549	NEEDS SIGN	E	
CHS-80		RM 102		CLASSROOM SINK	0.0012			
CHS-81		RM 102		CLASSROOM SINK	0.001			
CHS-82		RM 102		CLASSROOM SINK		VALVE OFF		
CHS-83		RM 102		CLASSROOM SINK		VALVE OFF		
CHS-84		RM 102		CLASSROOM SINK	0.001			
CHS-85		RM 102		CLASSROOM SINK	0.0028			
CHS-86		RM 102		CLASSROOM SINK	0.0048			
CHS-87		RM 102		CLASSROOM SINK	0.0044			
CHS-88		RM 102		CLASSROOM SINK	0.0071			
CHS-89		RM 102		CLASSROOM SINK	0.0094			
CHS-90		RM 102		CLASSROOM SINK	0.0025			
CHS-91		RM 102		CLASSROOM SINK	0.0049			
CHS-92		RM 103		EYEWASH	0.19	NEEDS SIGN	E	
CHS-93		PREP ROOM		CLASSROOM SINK	1.83	NEEDS SIGN	E	
CHS-94		PREP ROOM		EYEWASH	0.247	NEEDS SIGN	E	
CHS-95		RM 104		EYEWASH	0.0324	NEEDS SIGN	E	
CHS-96		RM 202		CLASSROOM SINK	0.001			
CHS-97		RM 202		CLASSROOM SINK		VALVE OFF		
CHS-98		RM 202		CLASSROOM SINK	0.0101			

CHS-99		RM 202		CLASSROOM SINK	0.0042			
CHS-100		RM 202		EYEWASH	0.039	NEEDS SIGN	E	
CHS-101		PREP ROOM		CLASSROOM SINK	0.001			
CHS-102		PREP ROOM		EYEWASH	0.06505	NEEDS SIGN	E	
CHS-103		RM 202		CLASSROOM SINK	0.0102			
CHS-104		RM 202		CLASSROOM SINK	0.0042			
CHS-105		RM 202		CLASSROOM SINK	0.001			
CHS-106		RM 202		EYEWASH	0.111	NEEDS SIGN	E	
CHS-107		07 WING 2ND FLR. C.C.		SLOP SINK	0.0022			
CHS-108		RM 202			0.0037			
CHS-109		RM 206		CLASSROOM SINK	0.0027			
CHS-110		RM 206		CLASSROOM SINK	0.0013			
CHS-111		07 WING 2ND FLR FAC R.R.		BATHROOM SINK	0.001			
CHS-112		VOID		VOID		VOID		
CHS-113		MAIN OFFICE		KITCHEN SINK	0.001			
CHS-114		MAIN OFFICE R.R.		BATHROOM SINK	0.004			
CHS-115		29 WING 3RD FLR FAC. R.R.		BATHROOM SINK	0.0111			
CHS-116		29 WING 3RD FLR FAC. R.R.		FLOOR SPIGOT	0.0042			
CHS-117		29 WING 3RD FLR C.C.		SLOP SINK	0.0385	NEEDS LABEL	E	
CHS-118		GIRLS L.R. C.C.		SLOP SINK	0.0152	NEEDS LABEL	E	
CHS-119		GIRLS L.R. C.C.		SLOP SINK	0.0143			
CHS-120		29 WING B.R.		FLOOR SPIGOT	0.0069			
CHS-121		VOID		VOID		VOID		
CHS-122		VOID		VOID		VOID		
CHS-123		VOID		VOID		VOID		
CHS-124		PREP ROOM		CLASSROOM SINK				
CHS-125		PREP ROOM		EYEWASH	0.0874	NEEDS SIGN	E	
CHS-126		RM 205		CLASSROOM SINK	0.001			
CHS-127		RM 205		EYEWASH	0.0326	NEEDS SIGN	E	
CHS-128		RM 205		EYEWASH	0.0683	NEEDS SIGN	E	
CHS-129		RM 205		CLASSROOM SINK	0.0038			
CHS-130		RM 205		CLASSROOM SINK	0.101	VALVE OFF	E	
CHS-131		RM 204		CLASSROOM SINK	0.0027			
CHS-132		RM 204		EYEWASH	0.0509	NEEDS SIGN	E	
CHS-133		RM 204		CLASSROOM SINK	0.0157	VALVE OFF	E	
CHS-134		RM 204		CLASSROOM SINK	0.009			
CHS-135		RM 204		EYEWASH	0.0542	NEEDS SIGN	E	
CHS-136		GYM LOBBY BOYS R.R.		FLOOR SPIGOT	4.72	NEEDS SIGN	E	

CHS-137		BOYS LOCKER ROOM		FLOOR SPIGOT				
CHS-138		GYM LOBBY C.C.		SLOP SINK	0.0359	NEEDS SIGN	E	
CHS-139		GYM LOBBY C.C.		FLOOR SPIGOT	0.0039			
CHS-140				OUTSIDE SPIGOT	0.0177	NEEDS SIGN	E	
CHS-141		RM 114		CLASSROOM SINK	0.0162	ORDERED NEW	E	
CHS-142		RM 114		CLASSROOM SINK	0.0107			
CHS-143		RM 114		CLASSROOM SINK	0.0118			
CHS-144		RM 115		CLASSROOM SINK	0.0268	ORDERED NEW	E	
CHS-145		RM 115		CLASSROOM SINK	0.0068			
CHS-146		RM 116		CLASSROOM SINK	0.0103			
CHS-147		RM 116		EYEWASH	0.0381	NEEDS SIGN	E	
CHS-148		RM 116		CLASSROOM SINK	0.0053			
CHS-149		RM 116		CLASSROOM SINK	0.0086			
CHS-150		RM 116		CLASSROOM SINK	0.0323	ORDERED NEW	E	
CHS-151		RM 111		EYEWASH	0.0372	NEEDS SIGN	E	
CHS-152		RM 109		CLASSROOM SINK	0.0025			
CHS-153		RM 109		CLASSROOM SINK		VALVE OFF		
CHS-154		RM 109		CLASSROOM SINK		VALVE OFF		
CHS-155		RM 109		CLASSROOM SINK	0.0227	ORDERED NEW	E	
CHS-156		07 WING 1ST FLR		WATER FOUNTAIN	0.001			
CHS-157		07 WING 1ST FLR		WATER FOUNTAIN	0.001			
CHS-158		07 WING GIRLS 1ST FLR R.R.		BATHROOM SINK	0.001			
CHS-159		07 WING GIRLS 1ST FLR R.R.		BATHROOM SINK	0.001			
CHS-160		07 WING GIRLS 1ST FLR R.R.		FLOOR SPIGOT	11.8	NEEDS SIGN	E	
CHS-161		07 WING BOYS 1ST FLR. R.R.		BATHROOM SINK	0.0021			
CHS-162		07 WING BOYS 1ST FLR. R.R.		BATHROOM SINK	0.001			
CHS-163		07 WING BOYS 1ST FLR. R.R.		FLOOR SPIGOT	2.2	NEEDS SIGN	E	
CHS-164		RM 107		CLASSROOM SINK	0.0128			
CHS-165		RM 107		CLASSROOM SINK	0.0078			
CHS-166		RM 107		CLASSROOM SINK	0.0067			
CHS-167		RM 107		CLASSROOM SINK	0.0078			
CHS-168		RM 107		CLASSROOM SINK	0.0112			
CHS-169		RM 107		CLASSROOM SINK	0.0061			
CHS-170		RM 107		CLASSROOM SINK		VALVE OFF		
CHS-171		RM 107		CLASSROOM SINK		VALVE OFF		
CHS-172		RM 107		CLASSROOM SINK	0.0053			
CHS-173		RM 107		CLASSROOM SINK	0.0074			
CHS-174		RM 107		CLASSROOM SINK		VALVE OFF		

CHS-175		RM 107		CLASSROOM SINK		VALVE OFF		
CHS-176		RM 107		CLASSROOM SINK	0.0066			
CHS-177		RM 107		EYEWASH	0.049	NEEDS SIGN	E	
CHS-178		PREP ROOM		CLASSROOM SINK	0.0033			
CHS-179		PREP ROOM		EYEWASH	0.205	NEEDS SIGN	E	
CHS-180		RM 106		CLASSROOM SINK	0.0103			
CHS-181		RM 106		CLASSROOM SINK	0.0046			
CHS-182		RM 106		CLASSROOM SINK	0.0075			
CHS-183		RM 106		CLASSROOM SINK	0.0047			
CHS-184		RM 106		CLASSROOM SINK	0.006			
CHS-185		RM 106		CLASSROOM SINK	0.0095			
CHS-186		RM 106		CLASSROOM SINK	0.0043			
CHS-187		RM 106		CLASSROOM SINK	0.0037			
CHS-188		RM 106		CLASSROOM SINK	0.001			
CHS-189		RM 106		CLASSROOM SINK	0.0094			
CHS-190		RM 106		CLASSROOM SINK	0.0075			
CHS-191		RM 110		CLASSROOM SINK	0.534	ORDERED NEW	E	
CHS-192		RM 110		EYEWASH	0.383	NEEDS SIGN	E	
CHS-193		RM 110		CLASSROOM SINK	1.43	ORDERED NEW	E	
CHS-194		RM 110		EYEWASH	0.124	NEEDS SIGN	E	
CHS-195		RM 110		CLASSROOM SINK		ORDERED NEW		
CHS-196		RM 109		CLASSROOM SINK	0.001			
CHS-197		07 WING 1ST FLR C.C.		SLOP SINK	0.001			
CHS-198		RM 106		CLASSROOM SINK	0.001			
CHS-199		RM 106		EYEWASH	1.32	NEEDS SIGN	E	
CHS-200		RM 106		CLASSROOM SINK	0.0063			
CHS-201		GYM LOBBY C.C.		SLOP SINK	0.0183	NEEDS SIGN	E	
CHS-202		GYM LOBBY C.C.		SLOP SINK	0.105	NEEDS SIGN	E	
CHS-203		TRAINERS OFFICE		BATHROOM SINK	0.001			
CHS-204		GYM LOBBY BOYS R.R.		BATHROOM SINK		NOT WORKING		
CHS-205		GYM LOBBY BOYS R.R.		BATHROOM SINK	0.001			
CHS-206		GYM LOBBY BOYS R.R.		FLOOR SPIGOT	0.76	NEEDS SIGN	E	
CHS-207		GYM LOBBY GIRLS R.R.		BATHROOM SINK	0.001			
CHS-208		GYM LOBBY GIRLS R.R.		BATHROOM SINK	0.001			
CHS-209		GYM LOBBY GIRLS R.R.		FLOOR SPIGOT	3.81	NEEDS SIGN	E	
CHS-210		GYM LOBBY		WATER FOUNTAIN	0.001			
CHS-211		GYM LOBBY		WATER FOUNTAIN	0.001			
CHS-212		GYM LOBBY COSESSION		KITCHEN SINK	0.001			

CHS-213		GIRLS LOCKER ROOM		WATER FOUNTAIN		INSTALLED NEW		
CHS-214		GIRLS LOCKER ROOM		WATER FOUNTAIN	0.0661	INSTALLED NEW		
CHS-215		GIRLS LOCKER ROOM COACH OFFICE		BATHROOM SINK	0.001			
CHS-216		GIRLS LOCKER ROOM R.R.		BATHROOM SINK	0.0027			
CHS-217		GIRLS LOCKER ROOM R.R.		BATHROOM SINK	0.001			
CHS-218		DANCE STUDIO		BATHROOM SINK	0.001			
CHS-219		DANCE STUDIO		BATHROOM SINK	0.0084			
CHS-220		GIRLS LOCKER ROOM		FLOOR SPIGOT	0.0385	NEEDS SIGN	E	
CHS-221		GIRLS LOCKER ROOM		FLOOR SPIGOT	0.0215	NEEDS SIGN	E	
CHS-222		80 WING		WATER FOUNTAIN	0.0019			
CHS-223		80 WING		WATER FOUNTAIN	0.0011			
CHS-224		80 WING GIRLS R.R.		BATHROOM SINK	0.0023			
CHS-225		80 WING GIRLS R.R.		BATHROOM SINK	0.0043			
CHS-226		80 WING GIRLS R.R.		FLOOR SPIGOT	1.5	NEEDS SIGN	E	
CHS-227		DISH WASHER ROOM		KITCHEN SINK	0.0057			
CHS-228		CAFÉ		WATER FOUNTAIN	0.0011			
CHS-229		NURSES OFFICE		BATHROOM SINK	0.0052			
CHS-230		NURSES OFFICE R.R.		BATHROOM SINK	0.0042			
CHS-231		63 WING GIRLS R.R.		BATHROOM SINK	0.0018			
CHS-232		63 WING GIRLS R.R.		BATHROOM SINK	0.0017			
CHS-233		63 WING GIRLS R.R.		FLOOR SPIGOT	0.389	NEEDS SIGN	E	
CHS-234		63 WING OUTSIDE NURSE OFFICE		WATER FOUNTAIN	0.0037			
CHS-235		63 WING C.C.		SLOP SINK	0.0228	NEEDS SIGN	E	
CHS-236		63 WING C.C.		SLOP SINK	0.0376	NEEDS SIGN	E	
CHS-237		63 WING FAC. RM TEACHERS CENTER		KITCHEN SINK	0.0016			
CHS-238		63 WING FAC. RM B.R. TEACHERS CENTER		BATHROOM SINK	0.0015			
CHS-239		63 WING FAC. RM MENS B.R. TEACHERS CENTER		BATHROOM SINK	0.0029			
CHS-240		63 WING FAC. RM LADIES B.R. TEACHER CENTER		BATHROOM SINK	0.0028			
CHS-241		63 WING FAC. RM LADIES B.R. TEACHER CENTER		BATHROOM SINK	0.0047			
CHS-242		63 WING BOYS R.R.		BATHROOM SINK	0.0021			
CHS-243		63 WING BOYS R.R.		BATHROOM SINK	0.0022			
CHS-244		63 WING BOYS R.R.		FLOOR SPIGOT	3.3	NEEDS SIGN	E	
CHS-245		NURSES OFFICE		EYEWASH	0.0049			
CHS-246		63 WING MENS R.R.		BATHROOM SINK	0.0033			
CHS-247		63 WING LADIES R.R.		BATHROOM SINK	0.002			
CHS-248		63 WING 1ST FLR BOYS R.R.		BATHROOM SINK	0.0023			
CHS-249		63 WING 1ST FLR BOYS R.R.		BATHROOM SINK	0.0018			
CHS-250		63 WING 1ST FLR BOYS R.R.		BATHROOM SINK	0.0018			

CHS-251	63 WING 1ST FLR BOYS R.R.	FLOOR SPIGOT	6.02	NEEDS SIGN	E
CHS-252	63 WING 1ST FLR C.C.	SLOP SINK	0.009		
CHS-253	63 WING 1ST FLR	WATER FOUNTAIN	0.0038		
CHS-254	63 WING 1ST FLR	WATER FOUNTAIN	0.002		
CHS-255	63 WING 1ST FLR GIRLS R.R.	BATHROOM SINK	0.001		
CHS-256	63 WING 1ST FLR GIRLS R.R.	BATHROOM SINK	0.001		
CHS-257	63 WING 1ST FLR GIRLS R.R.	BATHROOM SINK	0.0019		
CHS-258	63 WING 1ST FLR GIRLS R.R.	FLOOR SPIGOT	2.59	NEEDS SIGN	E
CHS-259	RM 111	CLASSROOM SINK	0.0312	INSTALLED NEW	
CHS-260	RM 111	CLASSROOM SINK	0.0128		
CHS-261	BOYS LOCKER ROOM	WATER FOUNTAIN	0.0439	INSTALLED NEW	E
CHS-262	BOYS LOCKER ROOM	WATER FOUNTAIN	0.0185	INSTALLED NEW	E
CHS-263	BOYS LOCKER ROOM C.C.	FLOOR SPIGOT	0.0447	NEEDS SIGN	E
CHS-264	BOYS LOCKER ROOM C.C.	FLOOR SPIGOT	0.0278	NEEDS SIGN	E
CHS-265	BOYS LOCKER ROOM R.R.	BATHROOM SINK	0.0086		
CHS-266	BOYS LOCKER ROOM COACHES BATHROOM	BATHROOM SINK	0.0054		
CHS-267	BOYS LOCKER ROOM	BATHROOM SINK	0.0064		
CHS-268	80 WING C.C.	FLOOR SPIGOT	0.034	NEEDS SIGN	E
CHS-269	80 WING C.C.	SLOP SINK	0.0018		
CHS-270	80 WING BOYS R.R.	BATHROOM SINK	0.0029		
CHS-271	80 WING BOYS R.R.	BATHROOM SINK	0.0025		
CHS-272	80 WING BOYS R.R.	BATHROOM SINK	0.002		
CHS-273	80 WING BOYS R.R.	FLOOR SPIGOT	0.677	NEEDS SIGN	E
CHS-274	KITCHEN	HAND WASH	0.0028		
CHS-275	OLD SCHOOL STORE	FLOOR SPIGOT	0.672	NEEDS SIGN	E
CHS-276	KITCHEN BETWEEN FREEZERS	FLOOR SPIGOT	0.0059	NEEDS SIGN	
CHS-277	KITCHEN C.C.	SLOP SINK	0.0309	NEEDS SIGN	
CHS-278	KITCHEN R.R.	BATHROOM SINK	0.0088		
CHS-279	KITCHEN SINK	SPRAY HOSE	0.0026		
CHS-280	KITCHEN SINK	WASH SINK	0.0057		
CHS-281	KITCHEN SINK	WASH SINK	0.0026		
CHS-282	KITCHEN SINK	FOOD PREP	0.005		
CHS-283	KITCHEN SINK	2 BAY SINK	0.0016		
CHS-284	KITCHEN SINK	HAND WASH	0.0105		
CHS-285	KITCHEN SINK	SERVING LINE	0.0035		
CHS-286	KITCHEN SINK	HAND WASH	0.254	INSTALLED NEW	E
CHS-287	KITCHEN SINK	2 BAY SINK	0.0016		
CHS-288	STEAMER	KETTLE	0.059	INSTALLED NEW	E

CHS-289	STEAMER		KETTLE	0.0578	INSTALLED NEW	E
CHS-290	RM 118		CLASSROOM SINK	0.0021		
CHS-291	RM 118		CLASSROOM SINK	0.0022		
CHS-292	RM 113 DARK ROOM A		CLASSROOM SINK	0.0867	NEED SIGN	E
CHS-293	RM 113 DARK ROOM A		CLASSROOM SINK	0.0069		
CHS-294	RM 113 DARK ROOM A		CLASSROOM SINK	0.0115		
CHS-295	RM 113 DARK ROOM B		EYEWASH	0.004		
CHS-296	RM 113 DARK ROOM B		CLASSROOM SINK	0.006		
CHS-297	RM 113 DARK ROOM B		CLASSROOM SINK	0.0019		
CHS-298	RM 113 DARK ROOM B		CLASSROOM SINK	0.0036		
CHS-299	RM 113 DARK ROOM B		EYEWASH	0.0087		
CHS-300	RM 112		CLASSROOM SINK	0.0093		
CHS-301	29 WING 4TH FLR BY RM 404		WATER FOUNTAIN	0.003		
CHS-302	29 WING 4TH FLR HANDICAPPED R.R.		BATHROOM SINK	0.001		
CHS-303	29 WING 4TH FLR C.C.		SLOP SINK	0.0058		
CHS-304	29 WING 4TH FLR C.C.		SLOP SINK	0.0063		
CHS-305	29 WING 4TH FLR S.S. OFFICE		KITCHEN SINK	0.0157	INSTALLED NEW	E
CHS-306	29 WING 3RD FLR BOYS R.R.		BATHROOM SINK	0.0024		
CHS-307	29 WING 3RD FLR BOYS R.R.		BATHROOM SINK	0.0025		
CHS-308	29 WING 3RD FLR BOYS R.R.		BATHROOM SINK		PARTS ON ORDER	
CHS-309	29 WING 3RD FLR BOYS R.R.		FLOOR SPIGOT	0.104	NEEDS SIGN	E
CHS-310	29 WING 3RD FLR GIRLS R.R.		FLOOR SPIGOT	1.25	NEEDS SIGN	E
CHS-311	29 WING 3RD FLR GIRLS R.R.		BATHROOM SINK	0.0013		
CHS-312	29 WING 3RD FLR GIRLS R.R.		BATHROOM SINK	0.001		
CHS-313	29 WING 3RD FLR GIRLS R.R.		BATHROOM SINK	0.0018		
CHS-314	29 WING 3RD FLR BY RM 303		WATER FOUNTAIN			
CHS-315	29 WING 3RD FLR C.C.		FLOOR SPIGOT	0.0743	NEEDS SIGN	E
CHS-316	29 WING 3RD FLR C.C.		SLOP SINK	0.014	NEEDS SIGN	
CHS-317	29 WING 3RD FLR HANDICAPPED R.R.		BATHROOM SINK	0.0032		
CHS-318	29 WING CUSTODIAL BREAK RM		KITCHEN SINK	0.001		
CHS-319	29 WING COLUCCI OFFICE		KITCHEN SINK	0.0019		
CHS-320	29 WING 2ND FLR C.C.		SLOP SINK	0.0059		
CHS-321	29 WING 2ND FLR C.C.		SLOP SINK	0.0093		
CHS-322	29 WING 2ND FLR OUTSIDE ART ROOMS		WATER FOUNTAIN		NOT WORKING	
CHS-323	RM 233		CLASSROOM SINK	0.0028		
CHS-324	RM 232		CLASSROOM SINK	0.0017		
CHS-325	OLD MAINT. SHOP		KITCHEN SINK	0.0153	REMOVED SINK AND F.E	
CHS-326	63 WING 2ND FLR MATH OFFICE		KITCHEN SINK	0.0024		

CHS-327	RM 214	CLASSROOM SINK	0.0195		E
CHS-328	RM 213 BUSINESS OFFICE	KITCHEN SINK	0.0167	INSTALLED NEW	E
CHS-329	RM 210	KITCHEN SINK	0.001		
CHS-330	63 WING 2ND FLR GIRLS R.R.	BATHROOM SINK	0.001		
CHS-331	63 WING 2ND FLR GIRLS R.R.	BATHROOM SINK	0.001		
CHS-332	63 WING 2ND FLR GIRLS R.R.	BATHROOM SINK	0.001		
CHS-333	63 WING 2ND FLR GIRLS R.R.	FLOOR SPIGOT	0.55	NEEDS SIGN	E
CHS-334	63 WING 2ND FLR	WATER FOUNTAIN	0.001		
CHS-335	63 WING 2ND FLR	WATER FOUNTAIN	0.0064		
CHS-336	63 WING 2ND FLR C.C.	SLOP SINK	0.0069		
CHS-337	63 WING 2ND FLR C.C.	SLOP SINK	0.001		
CHS-338	63 WING 2ND FLR BOYS R.R.	BATHROOM SINK	0.017		
CHS-339	63 WING 2ND FLR BOYS R.R.	BATHROOM SINK	0.001		
CHS-340	63 WING 2ND FLR BOYS R.R.	BATHROOM SINK	0.001		
CHS-341	63 WING 2ND FLR BOYS R.R.	FLOOR SPIGOT	0.681	NEEDS SIGN	E
CHS-342	07 WING 2ND FLR GIRLS R.R.	BATHROOM SINK	0.0067		
CHS-343	07 WING 2ND FLR GIRLS R.R.	BATHROOM SINK	0.001		
CHS-344	07 WING 2ND FLR GIRLS R.R.	FLOOR SPIGOT	0.37	NEEDS SIGN	E
CHS-345	07 WING 2ND FLR	WATER FOUNTAIN	0.001		
CHS-346	07 WING 2ND FLR	WATER FOUNTAIN	0.001		
CHS-347	07 WING 2ND FLR BOYS R.R.	BATHROOM SINK	0.001		
CHS-348	07 WING 2ND FLR BOYS R.R.	BATHROOM SINK	0.001		
CHS-349	07 WING 2ND FLR BOYS R.R.	FLOOR SPIGOT	0.959	NEEDS SIGN	E
CHS-350	RM 207	CLASSROOM SINK	0.0146		
CHS-351	RM 207	EYEWASH	0.0331	NEEDS SIGN	E
CHS-352	RM 207	CLASSROOM SINK	0.0022		
CHS-353	RM 207	CLASSROOM SINK	0.0062		
CHS-354	RM 207	CLASSROOM SINK	0.0062		
CHS-355	RM 207	CLASSROOM SINK	0.0023		
CHS-356	RM 207	CLASSROOM SINK	0.0013		
CHS-357	RM 207	CLASSROOM SINK	0.0059		
CHS-358	RM 207	CLASSROOM SINK	0.0025		
CHS-359	RM 207	EYEWASH	0.0442	NEEDS SIGN	E
CHS-360	PREP ROOM	CLASSROOM SINK	0.004		
CHS-361	PREP ROOM	EYEWASH	0.703	NEEDS SIGN	E
CHS-362	RM 206	CLASSROOM SINK	0.001		
CHS-363	RM 206	EYEWASH	0.19	NEEDS SIGN	E
CHS-364	RM 206	CLASSROOM SINK	0.001		

CHS-365		RM 206		CLASSROOM SINK	0.002			
CHS-366		RM 206		CLASSROOM SINK	0.0022			
CHS-367		RM 206		CLASSROOM SINK	0.001			
CHS-368		RM 206		CLASSROOM SINK	0.001			
CHS-369		RM 206		CLASSROOM SINK	0.001			
CHS-370		RM 206		CLASSROOM SINK	0.001			
CHS-371		RM 206		CLASSROOM SINK	0.0043			
CHS-372		RM 206		CLASSROOM SINK	0.001			
CHS-373		RM 206		CLASSROOM SINK	0.001			
CHS-374		RM 206		CLASSROOM SINK	0.0255		E	
CHS-375		RM 206		EYEWASH	0.0749	NEEDS SIGN	E	
CHS-376		RM 203		CLASSROOM SINK	0.0392		E	
CHS-377		RM 203		CLASSROOM SINK	0.001			
CHS-378		RM 203		CLASSROOM SINK	0.001			
CHS-379		RM 203		CLASSROOM SINK	0.0011			
CHS-380		RM 203		CLASSROOM SINK	0.001			
CHS-381		RM 203		CLASSROOM SINK	0.0055			
CHS-382		RM 203		CLASSROOM SINK	0.001			
CHS-383		RM 203		CLASSROOM SINK	0.001			
CHS-384		RM 203		CLASSROOM SINK	0.001			
CHS-385		RM 203		EYEWASH	0.0629	NEEDS SIGN	E	
CHS-386		63 WING 1ST FLR FAC. RM		KITCHEN SINK	0.0023			
CHS-387		07 WING 1ST FLR FAC. R.R		FLOOR SPIGOT	13.7	NEEDS SIGN	E	