

November 11, 2016

Water Testing Update

Dear Members of the Port Chester School Community:

This is to inform you that all water testing for lead, which began on September 17, 2016, has been completed in our schools and all necessary remediation has been implemented.

This letter is a follow up of the information distributed and posted on November 4, 2016.

On November 10, we received the Warren Panzer Engineers' water testing reports. Water testing began September 17, 2016. Every water outlet (i. e. sinks, fountains, hose connections) in the school district were tested and retested if necessary. The tests were conducted in compliance with the requirements of a new law recently passed by the New York State legislature (A10740/S8158) and the regulations adopted by the New York State Department of Health (10 NYCRR Subpart 67-4) regarding lead in school drinking water.

Background

The drinking water for the Village of Port Chester and its schools is supplied by the United Water Company. Municipal mains enter the school buildings to distribute water to the buildings' outlets and no additional treatment is applied to the water before distribution.

Subpart 67-4 requires public schools in New York State to test drinking water for lead. While first draw samples are required, we also conducted 30-second flush sample testing as recommended by the Westchester County Department of Health. A "first-draw" sample is a 250 milliliters (ml) sample collected from an outlet after the water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours.

Sampling and Analysis

Warren Panzer collected a first draw and 30-second flush sample water sample from every outlet in the school district. The collection bottles and samples were both supplied and analyzed by the Con-test Analytical Laboratory, a New York State-certified testing firm (NYS DOH ELAP #10899) in East Longmeadow, MA. Water samples were analyzed for lead Parts per Billion (ppb) using Method EPA 200.8.

Corrective Actions

NYS Subpart 67.4 requires that any drinking water outlet that exceeds 15 ppb be taken out of service or turned off until a remediation plan is implemented and re-testing shows lead levels below 15 ppb. Remediation actions include:

- Outlets used for drinking or cooking can be shut off and taken out of service.
- Outlets used only for handwashing or cleaning are identified with "Handwashing Only" signs --- drinking is prohibited from these outlets.
- Outdoor outlets only for maintenance or groundskeeping are used after a 60-second flush with appropriate signs posted.
- Water filters are installed as needed and replaced every 6 months.
- Plumbing (i. e. water lines, fittings, connections), which delivers water to outlets is examined and will be replaced as needed.

All outlets tested above 15 ppb were retested and remediated as indicated in the testing results cited in the following:

WATER TESTING AND REMEDIATION REPORT - NOVEMBER 11, 2016

- 1 Install and monitor "Hand Washing ONLY" signage
- 2 Take out of service / Remediate / Retest
- 3 Permanently take out of service
- 4 No Action Required
- 5 Retest only
- 6 Install sign "not for drinking" and flush 60 seconds before use for maintenance/ground keeping

Note that "ND" means "none detected"

								Results from follow up test as required	Results from follow up test as required	
				Initial Test	Results	Results				
School	Sample	Detail	Test Date	1st Draw (PPB)	2nd Draw (PPB)	Acceptable Limit (PPB)	Remediation / Corrective Action Plan	1st Draw	2nd Draw	Remediation / Corrective Action Plan
Park	1	fountain B002	9/17/2016	0.89	0.81	15.00	No Action Required			No Action Required
Park	2	sink B002	9/17/2016	1.30	0.87	15.00	No Action Required			No Action Required
Park	3	fountain B001	9/17/2016	0.80	0.75	15.00	No Action Required			No Action Required
Park	4	sink B001	9/17/2016	1.40	0.80	15.00	No Action Required			No Action Required
Park	5	fountain hall 50	9/17/2016	6.30	1.20	15.00	No Action Required			No Action Required
Park	6	fountain B005	9/17/2016	0.96	0.89	15.00	No Action Required			No Action Required
Park	7	sink B005	9/17/2016	1.50	0.85	15.00	No Action Required			No Action Required
Park	8	fountain B006	9/17/2016	0.98	1.00	15.00	No Action Required			No Action Required
Park	9	sink B006	9/17/2016	1.60	0.97	15.00	No Action Required			No Action Required
Park	10	fountain hall BO 10.1	9/17/2016	0.64	0.63	15.00	No Action Required			No Action Required
Park	11	sink café boys bath rm 10.2	9/17/2016	2.80	0.89	15.00	No Action Required			No Action Required
Park	12	sink prep kitchen	9/17/2016	2.30	0.87	15.00	No Action Required			No Action Required
Park	13	sink DW kitchen	9/17/2016	2.60	0.72	15.00	No Action Required			No Action Required
Park	14	sink DW kitchen	9/17/2016	2.00	0.86	15.00	No Action Required			No Action Required
Park	15	sink DW kitchen	9/17/2016	2.30	0.79	15.00	No Action Required			No Action Required
Park	16	sink B1ND kitchen bath	9/17/2016	1.90	0.93	15.00	No Action Required			No Action Required
Park	17	fountain right outside 103	9/17/2016	0.76	0.75	15.00	No Action Required			No Action Required

Park	18	fountain left outside 103	9/17/2016	0.78	0.77	15.00	No Action Required	No Action Required
Park	19	fountain 102	9/17/2016	1.10	0.88	15.00	No Action Required	No Action Required
Park	20	sink 102	9/17/2016	1.30	0.84	15.00	No Action Required	No Action Required
Park	21	fountain 101	9/17/2016	0.73	0.74	15.00	No Action Required	No Action Required
Park	22	sink 101	9/17/2016	0.91	0.77	15.00	No Action Required	No Action Required
Park	23	fountain 100	9/17/2016	1.00	0.88	15.00	No Action Required	No Action Required
Park	24	sink 100	9/17/2016	1.50	0.86	15.00	No Action Required	No Action Required
Park	25	sink teachers room 108.1	9/17/2016	7.80	0.96	15.00	No Action Required	No Action Required
Park	26	sink 111.3 principals bath	9/17/2016	1.30	1.20	15.00	No Action Required	No Action Required
Park	27	out of service	9/17/2016	NA	NA	15.00	No Action Required	No Action Required
Park	27A	fountain main entrance	9/17/2016	1.60	1.40	15.00	No Action Required	No Action Required
Park	28	sink open Door rm 120	9/17/2016	3.60	1.20	15.00	No Action Required	No Action Required
Park	29	sink nurses office rm119	9/17/2016	3.70	1.30	15.00	No Action Required	No Action Required
Park	30	skip	9/17/2016	NA	NA	15.00	No Action Required	No Action Required
Park	31	fountain 203	9/17/2016	0.94	0.98	15.00	No Action Required	No Action Required
Park	32	sink 203	9/17/2016	1.40	0.95	15.00	No Action Required	No Action Required
Park	33	fountain 201	9/17/2016	0.84	1.10	15.00	No Action Required	No Action Required
Park	34	sink 201	9/17/2016	1.20	1.10	15.00	No Action Required	No Action Required
Park	35	fountain 200	9/17/2016	0.86	1.10	15.00	No Action Required	No Action Required
Park	36	sink 200	9/17/2016	1.20	1.10	15.00	No Action Required	No Action Required
Park	37	fountain outside 207	9/17/2016	1.20	0.94	15.00	No Action Required	No Action Required
Park	38	sink 208	9/17/2016	38.00	3.30	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Park	39	fountain outside 215	9/17/2016	0.90	0.85	15.00	No Action Required	No Action Required
Park	40	fountain playground right	9/17/2016	0.87	0.85	15.00	No Action Required	No Action Required
Park	41	fountain playground left	9/17/2016	1.30	0.76	15.00	No Action Required	No Action Required
Park	42	Orthophosphate rm 215	9/17/2016	ND				
Park	43	Orthophosphate main	9/17/2016	ND				

Park	44	main lead sample	9/17/2016	18.00		15.00	Retest only	0.57	Retest below limits no action required
Park	45	sink B009	10/27/2016	4.20	0.64	15.00	No Action Required		No Action Required
King	1	sink 117 white	9/17/2016	17.00	48.00	15.00	Install and monitor "Hand Washing ONLY" signage		Install and monitor "Hand Washing ONLY" signage
King	2	fountain 117	9/17/2016	0.71	1.40	15.00	No Action Required		No Action Required
King	3	sink 117	9/17/2016	7.30	5.30	15.00	No Action Required		No Action Required
King	4	fountain 114	9/17/2016	ND	ND	15.00	No Action Required		No Action Required
King	5	sink 114	9/17/2016	2.00	ND	15.00	No Action Required		No Action Required
King	6	sink 115 white	9/17/2016	5.70	2.60	15.00	No Action Required		No Action Required
King	7	fountain 115	9/17/2016	0.69	1.10	15.00	No Action Required		No Action Required
King	8	sink 115	9/17/2016	3.10	1.10	15.00	No Action Required		No Action Required
King	9	fountain 130	9/17/2016	11.00	2.10	15.00	No Action Required		No Action Required
King	10	sink 130	9/17/2016	6.20	2.00	15.00	No Action Required		No Action Required
King	11	fountain outside rm 130	9/17/2016	2.10	2.00	15.00	No Action Required		No Action Required
King	12	fountain 128	9/17/2016	3.00	1.50	15.00	No Action Required		No Action Required
King	13	sink 128	9/17/2016	6.50	1.10	15.00	No Action Required		No Action Required
King	14	fountain 126	9/17/2016	ND	ND	15.00	No Action Required		No Action Required
King	15	sink 126	9/17/2016	4.50	0.51	15.00	No Action Required		No Action Required
King	16	fountain 127	9/17/2016	6.70	0.74	15.00	No Action Required		No Action Required
King	17	sink 127	9/17/2016	6.60	0.85	15.00	No Action Required		No Action Required
King	18	fountain 124	9/17/2016	3.70	1.40	15.00	No Action Required		No Action Required
King	19	sink 124	9/17/2016	6.00	2.40	15.00	No Action Required		No Action Required
King	20	fountain 125	9/17/2016	3.30	1.20	15.00	No Action Required		No Action Required
King	21	sink 125	9/17/2016	5.50	1.30	15.00	No Action Required		No Action Required
King	22	fountain 122	9/17/2016	0.78	ND	15.00	No Action Required		No Action Required
King	23	sink 122	9/17/2016	2.10	ND	15.00	No Action Required		No Action Required
King	24	fountain 123	9/17/2016	ND	ND	15.00	No Action Required		No Action Required

King	25	sink 123	9/17/2016	0.93	ND	15.00	No Action Required			No Action Required Retest below limits and will replace filter every 6 months
King	26	sink nurse rm 140 fountain outside rm 142	9/17/2016	15.00	4.10	15.00	Take out of service / Remediate / Retest	1.6	ND	No Action Required
King	27	sink kitchen center prep144	9/17/2016	2.90	1.50	15.00	No Action Required			No Action Required
King	28	sink kitchen right prep 144	9/17/2016	2.00	0.88	15.00	No Action Required			No Action Required
King	29	sink DW left 144	9/17/2016	4.10	0.62	15.00	No Action Required			No Action Required
King	30	sink HW room 144	9/17/2016	9.60	4.40	15.00	No Action Required			No Action Required Retest below limits and will replace filter every 6 months
King	31	fountain 108	9/17/2016	5.60	15.00	15.00	Take out of service / Remediate / Retest	2.6	1.8	Install and monitor "Hand Washing ONLY" signage
King	32	sink 108	9/17/2016	3.60	15.00	15.00	Install and monitor "Hand Washing ONLY" signage			No Action Required
King	33	sink 110.1 men's bath	9/17/2016	3.50	2.50	15.00	No Action Required			No Action Required
King	34	sink 110 women's bath	9/17/2016	6.60	3.40	15.00	No Action Required			No Action Required
King	35	sink 109 teachers room	9/17/2016	3.20	2.80	15.00	No Action Required			No Action Required Retest below limits and will replace filter every 6 months
King	36	fountain 106	9/17/2016	54.00	9.40	15.00	Take out of service / Remediate / Retest	2.5	10	No Action Required
King	37	sink 106	9/17/2016	12.00	8.70	15.00	No Action Required			No Action Required
King	38	fountain 107	9/17/2016	4.80	5.20	15.00	No Action Required			No Action Required
King	39	sink 107	9/17/2016	2.40	6.50	15.00	No Action Required			No Action Required
King	40	fountain 104	9/17/2016	3.70	5.60	15.00	No Action Required			No Action Required
King	41	sink 104	9/17/2016	6.20	5.40	15.00	No Action Required			No Action Required
King	42	fountain 105	9/17/2016	0.66	3.10	15.00	Retest due to proximity to sink 105	120	4.4	Take out of service and retest on 11/9/16

King	44	sink 105	9/17/2016	4.70	23.00	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
King	45	fountain 102	9/17/2016	0.68	0.77	15.00	No Action Required	No Action Required
King	46	sink 102	9/17/2016	18.00	6.00	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
King	47	fountain 103	9/17/2016	0.68	4.20	15.00	No Action Required	No Action Required
King	48	sink 103	9/17/2016	6.00	0.98	15.00	No Action Required	No Action Required
King	49	fountain 101	9/17/2016	1.30	1.60	15.00	No Action Required	No Action Required
King	50	sink 101	9/17/2016	1.30	1.60	15.00	No Action Required	No Action Required
King	51	fountain 100	9/17/2016	0.79	2.20	15.00	No Action Required	No Action Required
King	52	sink 100	9/17/2016	1.10	2.00	15.00	No Action Required	No Action Required
King	53	Orthophosphate rm 100	9/17/2016	ND				
King	54	Orthophosphate Main	9/17/2016	ND				
King	55	main sample lead	9/17/2016	0.62		15.00	No Action Required	No Action Required
JFK Lower	1	sink in maintenance area	9/17/2016	3.10	1.70	15.00	No Action Required	No Action Required
JFK Lower	2	sink teachers room128	9/17/2016	1.10	1.80	15.00	No Action Required	No Action Required
JFK Lower	3	fountain 129	9/17/2016	7.40	5.10	15.00	No Action Required	No Action Required
JFK Lower	4	sink 129	9/17/2016	6.60	2.50	15.00	No Action Required	No Action Required
JFK Lower	5	fountain 130	9/17/2016	6.10	1.90	15.00	No Action Required	No Action Required
JFK Lower	6	sink 130	9/17/2016	5.60	1.80	15.00	No Action Required	No Action Required
JFK Lower	7	fountain outside 132	9/17/2016	0.52	0.53	15.00	No Action Required	No Action Required
JFK Lower	8	sink HW 102.0	9/17/2016	2.20	0.72	15.00	No Action Required	No Action Required
JFK Lower	9	sink prep kitchen 102.2	9/17/2016	1.30	0.70	15.00	No Action Required	No Action Required
JFK Lower	10	sink DW 102.2 right	9/17/2016	1.70	0.69	15.00	No Action Required	No Action Required
JFK Lower	11	sink DW 102.2	9/17/2016	1.70	0.92	15.00	No Action Required	No Action Required
JFK Lower	11A	kitchen prep sink	9/17/2016	1.20	0.66	15.00	No Action Required	No Action Required

JFK Lower	12	sink 101.5 principal	9/17/2016	6.60	2.60	15.00	No Action Required			No Action Required
JFK Lower	13	sink 101.2	9/17/2016	170.00	13.00	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage Retest below limits and will replace filter every 6 months
JFK Lower	14	sink Open Door 103 right	9/17/2016	3.30	29.00	15.00	Take out of service / Remediate / Retest	ND	ND	No Action Required
JFK Lower	15	sink nurse 103 left	9/17/2016	4.80	4.20	15.00	No Action Required			No Action Required
JFK Lower	16	sink 105	9/17/2016	5.90	1.40	15.00	No Action Required			No Action Required
JFK Lower	17	fountain 106	9/17/2016	7.70	1.40	15.00	No Action Required			No Action Required
JFK Lower	18	sink 106	9/17/2016	5.40	1.50	15.00	No Action Required			No Action Required
JFK Lower	19	fountain 108	9/17/2016	5.30	2.60	15.00	No Action Required			No Action Required
JFK Lower	20	sink 108	9/17/2016	6.10	3.30	15.00	No Action Required			No Action Required Retest below limits and will replace filter every 6 months
JFK Lower	21	fountain 110.1	9/17/2016	25.00	3.50	15.00	Take out of service / Remediate / Retest	0.95	ND	Install and monitor "Hand Washing ONLY" signage
JFK Lower	22	sink 110.1	9/17/2016	20.00	3.70	15.00	No Action Required			No Action Required
JFK Lower	23	fountain outside rm 116 right	9/17/2016	0.67	0.64	15.00	No Action Required			No Action Required
JFK Lower	24	fountain outside rm 116 left	9/17/2016	0.79	0.68	15.00	No Action Required			No Action Required
JFK Lower	25	fountain 116	9/17/2016	8.90	3.00	15.00	No Action Required			No Action Required
JFK Lower	26	sink 116	9/17/2016	11.00	3.40	15.00	No Action Required			No Action Required
JFK Lower	27	fountain 115	9/17/2016	5.60	4.70	15.00	No Action Required			No Action Required
JFK Lower	28	sink 115	9/17/2016	4.70	4.60	15.00	No Action Required			No Action Required
JFK Lower	28A	sink bathroom	9/17/2016	7.00	3.10	15.00	No Action Required			No Action Required
JFK Lower	29	fountain 114	9/17/2016	1.30	0.66	15.00	No Action Required			No Action Required
JFK Lower	30	sink 114	9/17/2016	5.10	2.20	15.00	No Action Required			No Action Required
JFK Lower	31	sink 113 bath	9/17/2016	4.10	1.70	15.00	No Action Required			No Action Required

JFK Lower	32	sink 112 bath	9/17/2016	1.50	0.95	15.00	No Action Required	No Action Required
JFK Lower	32A	Orthophosphate	9/17/2016	ND			No Action Required	No Action Required
JFK Lower	33	hose bib upper outside wall	9/17/2016	26.00	2.70	15.00	Install sign not for drinking flush 60 seconds	Install sign not for drinking flush 60 seconds
JFK Lower	33A	hose bib lower outside wall	9/17/2016	18.00	4.70	15.00	Install sign not for drinking flush 60 seconds	Install sign not for drinking flush 60 seconds
JFK Lower	34	hose bib planter #1	9/17/2016	36.00	5.30	15.00	Install sign not for drinking flush 60 seconds	Install sign not for drinking flush 60 seconds
JFK Lower	35	hose bib planter # 2	9/17/2016	23.00	4.50	15.00	Install sign not for drinking flush 60 seconds	Install sign not for drinking flush 60 seconds
JFK Lower	36	hose bib free standing	9/17/2016	39.00	2.90	15.00	Install sign not for drinking flush 60 seconds	Install sign not for drinking flush 60 seconds
JFK Lower	37	hose bib planter # 3	9/17/2016	25.00	7.60	15.00	Install sign not for drinking flush 60 seconds	Install sign not for drinking flush 60 seconds
JFK Lower	38	main sample lead	9/17/2016	4.50		15.00	No Action Required	No Action Required
JFK Lower	38A	Orthophosphate	9/17/2016	ND		15.00	No Action Required	No Action Required
JFKP primary	1	sink 112.2	9/17/2016	3.10	2.20	15.00	No Action Required	No Action Required
JFKP primary	2	fountain outside 112.2	9/17/2016	ND	ND	15.00	No Action Required	No Action Required
JFKP primary	3	sink 102 teachers lounge	9/17/2016	3.90	2.50	15.00	No Action Required	No Action Required
JFKP primary	4	fountain 103	9/17/2016	3.60	1.20	15.00	No Action Required	No Action Required
JFKP primary	5	sink 103	9/17/2016	2.60	1.50	15.00	No Action Required	No Action Required
JFKP primary	6	fountain 101	9/17/2016	2.40	1.60	15.00	No Action Required	No Action Required

JFKP	primary	7	sink 101	9/17/2016	2.80	2.00	15.00	No Action Required	No Action Required
JFKP	primary	8	fountain 110	9/17/2016	3.90	2.10	15.00	No Action Required	No Action Required
JFKP	primary	9	sink 110	9/17/2016	5.10	2.20	15.00	No Action Required	No Action Required
JFKP	primary	10	fountain 109	9/17/2016	3.40	1.60	15.00	No Action Required	No Action Required
JFKP	primary	11	sink 109	9/17/2016	10.00	1.80	15.00	No Action Required	No Action Required
JFKP	primary	12	fountain 108	9/17/2016	2.90	2.60	15.00	No Action Required	No Action Required
JFKP	primary	13	sink 108	9/17/2016	4.30	2.90	15.00	No Action Required	No Action Required
JFKP	primary	14	sink 107	9/17/2016	1.50	0.92	15.00	No Action Required	No Action Required
JFKP	primary	15	fountain 106	9/17/2016	2.10	1.90	15.00	No Action Required	No Action Required
JFKP	primary	16	sink 106	9/17/2016	4.40	1.90	15.00	No Action Required	No Action Required
JFKP	primary	17	sink 105	9/17/2016	1.60	1.30	15.00	No Action Required	No Action Required
JFKP	primary	18	Orthophosphate	9/17/2016	ND		15.00	No Action Required	No Action Required
JFKP	primary	19	lead sample boiler room	9/17/2016	2.30		15.00	No Action Required	No Action Required
JFKP	primary	20	boiler room Orthophosphate	9/17/2016	ND			No Action Required	No Action Required
ELC		1	sink 211	9/24/2016	59.00	15.00	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
ELC		2	fountain 113 café	9/24/2016	ND	ND	15.00	No Action Required	No Action Required
ELC		3	sink DW right kitchen 115	9/24/2016	15.00	4.40	15.00	Install signage dish washing only	Install signage dish washing only
ELC		4	sink DW left kitchen 115	9/24/2016	3.20	1.90	15.00	No Action Required	No Action Required
ELC		5	sink HW 115 kitchen	9/24/2016	8.90	0.83	15.00	No Action Required	No Action Required
ELC		6	sink prep right 115	9/24/2016	7.10	0.81	15.00	No Action Required	No Action Required
ELC		7	sink prep 115 left	9/24/2016	2.30	ND4	15.00	No Action Required	No Action Required
ELC		8	sink boys right café	9/24/2016	21.00	2.40	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
ELC		9	sink boys left café	9/24/2016	4.20	1.30	15.00	No Action Required	No Action Required

ELC	10	sink girls bath right café	9/24/2016	6.40	0.94	15.00	No Action Required	No Action Required
ELC	11	sink girls bath left	9/24/2016	10.00	0.94	15.00	No Action Required	No Action Required
ELC	12	sink room 100	9/24/2016	1.40	ND	15.00	No Action Required	No Action Required
ELC	13	sink 101 bath	9/24/2016	3.30	1.30	15.00	No Action Required	No Action Required
ELC	14	fountain outside 102	9/24/2016	0.85	1.40	15.00	No Action Required	No Action Required
ELC	15	sink boys bath ist floor right	9/24/2016	1.80	0.69	15.00	No Action Required	No Action Required
ELC	16	sink boys bath 1st floor left	9/24/2016	6.20	0.81	15.00	No Action Required	No Action Required
ELC	17	fountain outside 104	9/24/2016	0.75	1.10	15.00	No Action Required	No Action Required
ELC	18	sink girls bath right 1st floor	9/24/2016	1.60	0.63	15.00	No Action Required	No Action Required
ELC	19	girls bath sink left 1st floor	9/24/2016	1.10	0.67	15.00	No Action Required	No Action Required
ELC	20	sink 107	9/24/2016	1.30	0.81	15.00	No Action Required	No Action Required
ELC	21	fountain outside 206	9/24/2016	4.40	4.00	15.00	No Action Required	No Action Required
ELC	22	sink girls bath right 2nd floor	9/24/2016	1.90	2.40	15.00	No Action Required	No Action Required
ELC	23	sink girls bath left 2nd floor	9/24/2016	1.60	1.90	15.00	No Action Required	No Action Required
ELC	24	sink boys bath right 2nd floor	9/24/2016	1.50	0.90	15.00	No Action Required	No Action Required
ELC	25	sink boys bath left 2nd floor	9/24/2016	2.00	0.88	15.00	No Action Required	No Action Required
ELC	26	fountain outside 204	9/24/2016	0.66	1.50	15.00	No Action Required	No Action Required
ELC	27	sink 202 teachers lounge	9/24/2016	2.60	0.84	15.00	No Action Required	No Action Required
ELC	28	sink bath 202	9/24/2016	1.50	0.74	15.00	No Action Required	No Action Required
ELC	29	Orthophosphate 202	9/24/2016	ND			No Action Required	No Action Required
ELC	30	main sample lead	9/24/2016	3.20		15.00	No Action Required	No Action Required
ELC	31	Orthophosphate main	9/24/2016	ND			No Action Required	No Action Required
Edison	1	sink B007 right nurses	9/24/2016	4.30	1.40	15.00	No Action Required	No Action Required
Edison	1A	fountain outside left	9/24/2016	2.10	1.60	15.00	No Action Required	No Action Required
Edison	1B	fountain outside right	9/24/2016	2.10	1.70	15.00	No Action Required	No Action Required
Edison	2	sink B007 left nurses	9/24/2016	1.40	1.10	15.00	No Action Required	No Action Required
Edison	3	sink B007.1 bath	9/24/2016	0.72	0.71	15.00	No Action Required	No Action Required
Edison	4	sink B006 custodian	9/24/2016	3.90	0.64	15.00	No Action Required	No Action Required
Edison	5	fountain B002 right	9/24/2016	ND	ND	15.00	No Action Required	No Action Required

Edison	6	fountain B002 left	9/24/2016	ND	0.51	15.00	No Action Required	No Action Required
Edison	7	sink prep kitchen B001	9/24/2016	2.40	ND	15.00	No Action Required	No Action Required
Edison	8	sink prep wall B001	9/24/2016	3.60	ND	15.00	No Action Required	No Action Required
Edison	9	sink DW right B001	9/24/2016	0.66	ND	15.00	No Action Required	No Action Required
Edison	10	sink DW left B001	9/24/2016	1.40	ND	15.00	No Action Required	No Action Required
Edison	10A	sink HW B001	9/24/2016	10.00	0.60	15.00	No Action Required	No Action Required
Edison	11	sink 101.1principals office	9/24/2016	5.10	1.00	15.00	No Action Required	No Action Required
							Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Edison	12	sink 100.1 sink fountain outside	9/24/2016	51.00	1.30	15.00	No Action Required	No Action Required
Edison	13	106	9/24/2016	1.50	0.75	15.00	No Action Required	No Action Required
Edison	14	sink in 110.2	9/24/2016	3.70	0.59	15.00	No Action Required	No Action Required
Edison	15	sink 111.1	9/24/2016	3.10	0.69	15.00	No Action Required	No Action Required
Edison	16	sink 112.1	9/24/2016	1.70	0.63	15.00	No Action Required	No Action Required
Edison	17	fountain 10.1 outside 112	9/24/2016	0.65	ND	15.00	No Action Required	No Action Required
Edison	18	sink 113.1	9/24/2016	2.20	0.66	15.00	No Action Required	No Action Required
Edison	19	sink 119.1	9/24/2016	0.93	0.61	15.00	No Action Required	No Action Required
Edison	20	sink 119.1	9/24/2016	0.98	ND	15.00	No Action Required	No Action Required
Edison	21	sink 120.1	9/24/2016	1.20	0.58	15.00	No Action Required	No Action Required
Edison	22	fountain 120	9/24/2016	1.00	ND	15.00	No Action Required	No Action Required
Edison	23	sink 120	9/24/2016	0.84	ND	15.00	No Action Required	No Action Required
Edison	24	sink 121.1	9/24/2016	1.30	0.58	15.00	No Action Required	No Action Required
Edison	25	fountain 121	9/24/2016	0.80	ND	15.00	No Action Required	No Action Required
Edison	26	sink 121	9/24/2016	1.40	ND	15.00	No Action Required	No Action Required
							Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Edison	27	sink 200.1 teachers bathroom	9/24/2016	18.00	1.50	15.00	No Action Required	No Action Required
Edison	28	sink 200 teachers room	9/24/2016	9.50	1.20	15.00	No Action Required	No Action Required
Edison	29	sink 201	9/24/2016	4.80	0.91	15.00	No Action Required	No Action Required

Edison	30	fountain outside 206	9/24/2016	1.50	1.10	15.00	No Action Required			No Action Required
Edison	31	fountain outside 212	9/24/2016	ND	---	15.00	No Action Required			No Action Required
Edison	32	Orthophosphate outside 212	9/24/2016	ND			No Action Required			No Action Required
Edison	33	main sample lead	9/24/2016	45.00		15.00	Retest only	42	1.5	Retest below limits no action required
Edison	34	Orthophosphate main	9/24/2016	ND			No Action Required			No Action Required
Edison	35	sink B011	11/1/2016	1.10	ND		No Action Required			No Action Required
Middle school	1	fountain outside 123	9/30/2016	ND	ND	15.00	No Action Required			No Action Required
Middle school	2	fountain outside 137 B&G	9/30/2016	2.00	1.70	15.00	No Action Required			No Action Required
Middle school	3	sink 137.5	9/30/2016	5.50	1.30	15.00	No Action Required			No Action Required
Middle school	4	sink 137.4 bathroom	9/30/2016	6.60	6.70	15.00	No Action Required			No Action Required
Middle school	5	sink 146.1 bathroom custodian	9/30/2016	4.80	2.40	15.00	No Action Required			No Action Required
Middle school	6	sink 105 A	9/30/2016	93.00	29.00	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	7	sink 105 B	9/30/2016	750.00	29.00	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	8	sink 105 C	9/30/2016	16.00	7.20	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	9	sink 105 D	9/30/2016	30.00	6.70	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	10	sink 121	9/30/2016	20.00	7.60	15.00	Take out of service / Remediate / Retest	540	6.3	Retest 10/27/16 FD 1.5 & SD ND Replace filter every 6 months

Middle school	11	sink 121	9/30/2016	10.00	2.90	15.00	No Action Required	5.4	1	Retest below limits change filter every 6 months Install and monitor "Hand Washing ONLY" signage
Middle school	12	sink 121	9/30/2016	23.00	6.30	15.00	Take out of service / Remediate / Retest	71	4.7	Install and monitor "Hand Washing ONLY" signage
Middle school	13	sink 120	9/30/2016	86.00	66.00	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	14	sink 106	9/30/2016	32.00	2.70	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	15	sink 119	9/30/2016	180.00	73.00	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	16	sink 107 right	9/30/2016	89.00	4.70	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	17	sink 107 left	9/30/2016	40.00	1.80	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	18	sink 107 right	9/30/2016	56.00	3.50	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	19	sink 107 left	9/30/2016	8.70	1.80	15.00	No Action Required			No Action Required
Middle school	20	fountain outside 117	9/30/2016	1.40	ND	15.00	No Action Required			No Action Required
Middle school	21	fountain outside 109	9/30/2016	6.60	1.30	15.00	No Action Required			No Action Required
Middle school	22	sink 100.1 right	9/30/2016	19.00	7.10	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage

Middle school	23	sink 100.1 left	9/30/2016	31.00	6.50	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Middle school	24	sink 100.2 right	9/30/2016	49.00	5.30	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Middle school	25	sink 100.2 left	9/30/2016	7.00	1.70	15.00	No Action Required	No Action Required
Middle school	26	fountain outside 112 aux gym	9/30/2016	4.50	7.20	15.00	No Action Required	No Action Required
Middle school	27	sink 115.2	9/30/2016	120.00	13.00	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Middle school	28	sink 115.1 right	9/30/2016	9.60	9.40	15.00	No Action Required	No Action Required
Middle school	29	sink 115.2 left	9/30/2016	91.00	14.00	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Middle school	30	sink locker rm right 114.5	9/30/2016	42.00	15.00	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Middle school	31	sink locker rm center 114.5	9/30/2016	14.00	7.30	15.00	No Action Required	No Action Required
Middle school	32	sink locker rm left 114.5	9/30/2016	9.30	8.30	15.00	No Action Required	No Action Required
Middle school	33	sink 114.5 office	9/30/2016	56.00	5.40	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Middle school	34	fountain locker rm 114 boys	9/30/2016	8.60	6.20	15.00	No Action Required	No Action Required
Middle school	35	fountain 218.1 café A	9/30/2016	ND	ND	15.00	No Action Required	No Action Required
Middle school	36	fountain 218.2 café B	9/30/2016	ND	ND	15.00	No Action Required	No Action Required
Middle school	37	sink 224.2 HW kitchen	9/30/2016	18.00	2.80	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage

Middle school	38	sink 224.2 DW kitchen	9/30/2016	8.20	1.10	15.00	No Action Required	No Action Required
Middle school	39	sink 224.2 DW kitchen	9/30/2016	5.30	0.89	15.00	No Action Required	No Action Required
Middle school	40	sink 224.2 DW kitchen	9/30/2016	6.80	0.98	15.00	No Action Required	No Action Required
Middle school	41	Kettle 224 kitchen	9/30/2016	ND3	ND	15.00	No Action Required	No Action Required
Middle school	42	sink prep center 224	9/30/2016	4.80	1.20	15.00	No Action Required	No Action Required
Middle school	43	sink prep left 224	9/30/2016	2.20	0.95	15.00	No Action Required	No Action Required
Middle school	44	sink prep right 224	9/30/2016	2.40	ND	15.00	No Action Required	No Action Required
Middle school	45	sink 224.2 bathroom	9/30/2016	13.00	4.80	15.00	No Action Required	No Action Required
Middle school	46	fountain outside 222	9/30/2016	0.81	ND	15.00	No Action Required	No Action Required
Middle school	47	fountain outside 215	9/30/2016	1.60	ND	15.00	No Action Required	No Action Required
Middle school	48	sink 432 bath outside library	9/30/2016	4.40	0.89	15.00	No Action Required	No Action Required
Middle school	49	sink 230.1 library	9/30/2016	15.00	16.00	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Middle school	50	sink 211.1 right teachers bath	9/30/2016	3.90	1.50	15.00	No Action Required	No Action Required
Middle school	51	sink 211.1 left teachers bath	9/30/2016	1.40	1.20	15.00	No Action Required	No Action Required
Middle school	52	sink 211 teachers lounge	9/30/2016	0.96	ND8	15.00	No Action Required	No Action Required
Middle school	52A	sink 213 main office	9/30/2016	130.00	9.00	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Middle school	53	sink 213.5 woman's bath	9/30/2016	15.00	7.30	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Middle school	54	sink 213.6 men's bath	9/30/2016	23.00	4.50	15.00	Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
Middle school	55	fountain outside 213.5	9/30/2016	0.73	1.20	15.00	No Action Required	No Action Required
Middle school	56	sink 209 nurses main sink	9/30/2016	4.30	ND7	15.00	No Action Required	No Action Required

Middle school	57	sink 209.4 nurses bath	9/30/2016	37.00	6.70	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	58	sink 209.3 nurses bath	9/30/2016	23.00	1.70	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	59	fountain outside 226	9/30/2016	ND	ND	15.00	No Action Required			No Action Required
Middle school	60	sink 230A	9/30/2016	2.40	2.30	15.00	No Action Required			No Action Required
Middle school	61	sink 231 left	9/30/2016	140.00	9.30	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	61A	sink 231 Right	9/30/2016	74.00	9.90	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
Middle school	62	sink 232F band	9/30/2016	1.90	0.79	15.00	No Action Required			No Action Required
Middle school	63	fountain outside 203	9/30/2016	22.00	13.00	15.00	Take out of service / Remediate / Retest	1.6	18	Retest 10/27/16 2.5FD & .89 SD replace filter every 6 months
Middle school	64	fountain outside 320	9/30/2016	ND	ND	15.00	No Action Required			No Action Required
Middle school	65	fountain outside 309	9/30/2016	0.78	ND7	15.00	No Action Required			No Action Required
Middle school	66	fountain outside 312	9/30/2016	0.70	ND9	15.00	No Action Required			No Action Required
Middle school	67	Orthophosphate outside 312	9/30/2016	ND						
Middle school	68	Orthophosphate main	9/30/2016	ND						
Middle school	69 (P0)_	Outside Field fountain	9/30/2016	0.95	1.10	15.00	No Action Required			No Action Required
Middle school	70	Lead sample at main	10/13/2016	8.40		15.00	No Action Required			No Action Required
Middle school	71	M03 Room sink 121.12A	10/7/2016	120.00	73.00	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage

PCHS	1	sink B106.2	10/7/2016	2.10	1.70	15.00	No Action Required	No Action Required
PCHS	2	sink B111 right	10/7/2016	3.20	2.20	15.00	No Action Required	No Action Required
PCHS	3	sink B111 left	10/7/2016	3.60	1.80	15.00	No Action Required	No Action Required
PCHS	4	fountain outside B111	10/7/2016	1.60	2.30	15.00	No Action Required	No Action Required
PCHS	5	sink team locker room 118.1	10/7/2016	1.20	3.80	15.00	No Action Required	No Action Required
PCHS	6	sink team locker room 118.1	10/7/2016	4.10	1.50	15.00	No Action Required	No Action Required
PCHS	7	sink team locker room 118.1	10/7/2016	4.40	3.60	15.00	No Action Required	No Action Required
PCHS	8	sink team locker room 118.1	10/7/2016	4.10	6.50	15.00	No Action Required	No Action Required
PCHS	9	sink 114.4 left	10/7/2016	1.90	ND	15.00	No Action Required	No Action Required
PCHS	10	sink 114.4 right by locker room	10/7/2016	2.00	ND	15.00	No Action Required	No Action Required
PCHS	11	fountain girls locker room 118	10/7/2016	4.60	3.30	15.00	No Action Required	No Action Required
PCHS	12	sink 119 coaches office	10/7/2016	3.10	ND	15.00	No Action Required	No Action Required
PCHS	13	fountain café - B001	10/7/2016	ND	ND	15.00	No Action Required	No Action Required
PCHS	14	sink prep B005	10/7/2016	1.30	ND	15.00	No Action Required	No Action Required
PCHS	15	sink prep B005	10/7/2016	6.50	ND	15.00	No Action Required	No Action Required
PCHS	16	sink prep B005	10/7/2016	9.00	ND	15.00	No Action Required	No Action Required
PCHS	17	sink DW B005	10/7/2016	ND	ND	15.00	No Action Required	No Action Required
PCHS	18	sink DW B005	10/7/2016	ND	ND	15.00	No Action Required	No Action Required
PCHS	19	sink bath B008.1	10/7/2016	3.40	0.58	15.00	No Action Required	No Action Required
PCHS	19A	Kettle kitchen	10/7/2016	ND	ND	15.00	No Action Required	No Action Required
PCHS	20	sink 105.5 Open Door	10/7/2016	1.80	0.05	15.00	No Action Required	No Action Required
PCHS	21	sink 105.4 Open Door	10/7/2016	7.50	1.50	15.00	No Action Required	No Action Required
PCHS	22	sink 105.3 Open Door	10/7/2016	4.40	3.10	15.00	No Action Required	No Action Required
PCHS	23	sink 105.2 Open Door	10/7/2016	5.60	2.20	15.00	No Action Required	No Action Required
PCHS	24	fountain outside 106	10/7/2016	1.30	1.10	15.00	No Action Required	No Action Required
PCHS	25	sink 116.2 guidance	10/7/2016	2.10	0.63	15.00	No Action Required	No Action Required
PCHS	26	sink 118.5 main office	10/7/2016	2.80	1.20	15.00	No Action Required	No Action Required
PCHS	27	sink 120.1 principal	10/7/2016	3.80	ND	15.00	No Action Required	No Action Required
PCHS	28	sink 123.1 nurse bath	10/7/2016	4.70	1.10	15.00	No Action Required	No Action Required

PCHS	29	sink 123.1 nurse main area	10/7/2016	36.00	10.00	15.00	Take out of service / Remediate / Retest	14	0.55	Retest below limits and will replace filter every 6 months
PCHS	30	fountain outside 123.1	10/7/2016	0.83	1.10	15.00	No Action Required			No Action Required
PCHS	31	fountain outside main office-118	10/7/2016	2.80	1.10	15.00	No Action Required			No Action Required
PCHS	32	fountain outside 122.3	10/7/2016	5.40	2.10	15.00	No Action Required			No Action Required
PCHS	33	fountain outside 127	10/7/2016	1.10	1.50	15.00	No Action Required			No Action Required
PCHS	34	sink 124.6 bath	10/7/2016	4.30	0.80	15.00	No Action Required			No Action Required
PCHS	35	fountain outside 140	10/7/2016	2.50	0.94	15.00	No Action Required			No Action Required
PCHS	36	fountain outside 143 aux gym	10/7/2016	0.64	ND9	15.00	No Action Required			No Action Required
PCHS	37	sink 143.4	10/7/2016	3.00	ND	15.00	No Action Required			No Action Required Retest below limits and will replace filter every 6 months
PCHS	38	Ice machine 143.4	10/7/2016	160.00	6.30	15.00	Take out of service / Remediate / Retest	ND	ND	Retest below limits and will replace filter every 6 months
PCHS	39	sink 145.2	10/7/2016	12.00	0.56	15.00	No Action Required			No Action Required
PCHS	40	sink 141	10/7/2016	2.00	ND	15.00	No Action Required			No Action Required
PCHS	41	sink 147 teachers bath	10/7/2016	7.60	2.80	15.00	No Action Required			No Action Required
PCHS	42	sink 150 teachers room	10/7/2016	2.30	0.66	15.00	No Action Required			No Action Required
PCHS	43	sink 152	10/7/2016	31.00	2.50	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
PCHS	43A	sink left 107 bath	10/7/2016	21.00	2.60	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
PCHS	43B	sink right 107 bath	10/7/2016	21.00	3.50	15.00	Install and monitor "Hand Washing ONLY" signage			Install and monitor "Hand Washing ONLY" signage
PCHS	44	sink 254 left	10/7/2016	2.70	7.90	15.00	No Action Required			No Action Required
PCHS	45	sink 254 right	10/7/2016	2.80	8.50	15.00	No Action Required			No Action Required

PCHS	46	sink 255	10/7/2016	3.70	0.92	15.00	No Action Required	No Action Required
PCHS	47	sink 255	10/7/2016	1.70	0.87	15.00	No Action Required	No Action Required
PCHS	48	sink 253	10/7/2016	1.80	ND	15.00	No Action Required	No Action Required
PCHS	49	sink 253	10/7/2016	2.50	ND	15.00	No Action Required	No Action Required
							Install and monitor "Hand Washing ONLY" signage	Install and monitor "Hand Washing ONLY" signage
PCHS	50	sink 249 fountain outside	10/7/2016	30.00	3.00	15.00	No Action Required	No Action Required
PCHS	51	229 fountain outside	10/7/2016	3.20	ND	15.00	No Action Required	No Action Required
PCHS	52	227 fountain outside	10/7/2016	0.82	0.05	15.00	No Action Required	No Action Required
PCHS	53	220 fountain outside	10/7/2016	ND	0.57	15.00	No Action Required	No Action Required
PCHS	54	sink 208 fountain outside	10/7/2016	0.65	ND	15.00	No Action Required	No Action Required
PCHS	55	207 Orthophosphate	10/7/2016	ND	ND	15.00	No Action Required	No Action Required
PCHS	56	outside 207	10/7/2016	ND		15.00	No Action Required	No Action Required
PCHS	57	main sample lead Orthophosphate	10/7/2016	ND		15.00	No Action Required	No Action Required
PCHS	58	main	10/7/2016	ND		15.00	No Action Required	No Action Required
PCHS	59	hose bib shed fountain outside	10/7/2016	1.80	1.30	15.00	No Action Required	No Action Required
PCHS	60	field	10/7/2016	1.80	ND	15.00	No Action Required	No Action Required