



Microbac Laboratories, Inc., New York Division
 CERTIFICATE OF ANALYSIS

J7K1021

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Long Lake 5

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 11/09/2017
 Reported: 11/14/2017

Analytical Testing Parameters

Client Sample ID:	1	Collected By:	LS-Client
Sample Matrix:	Drinking Water	Collection Date:	11/03/2017 12:00
Lab Sample ID:	J7K1021-01		

Lead and/or Copper, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4								
Lead	0.00335	0.015 AL	0.000500	mg/L		11/13/17 1149	11/13/17 1418	NY

Client Sample ID:	2	Collected By:	LS-Client
Sample Matrix:	Drinking Water	Collection Date:	11/03/2017 12:03
Lab Sample ID:	J7K1021-02		

Lead and/or Copper, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Lab
Method: EPA 200.8/EPA 200.8, Rv 5.4								
Lead	0.00256	0.015 AL	0.000500	mg/L		11/13/17 1149	11/13/17 1418	NY

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
 RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
 NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Brenna Murray
 Sample Custodian
 Reported: 11/14/2017 17:01