



RegCom

Regulatory Compliance

Anthony Russo
 Tuckahoe UFSD
 65 Siwanoy Blvd
 Eastchester, NY 10709

August 7, 2016

Dear Mr. Russo,

RegCom completed a limited water testing throughout the district in April 10, 2016 and several sampling points were above the EPA Action Level. Following the investigation, the district remediated several sinks and water fountains. RegCom retested the following sampling points on July 22, 2016. The sampling points were below the EPA Action Level with the exception of the kitchen sink #3 as indicated below.

Location	1st Draw (mg/L)	2nd Draw (mg/L)	EPA Action Level (mg/L)	Comments
Cottle School				
Teacher's Lounge	0.013	0.001	0.015	Sink
Nurse's Office	0.003	0.001	0.015	Sink
Classrooms 42	0.001	0.001	0.015	Water Fountain
Kitchen Sink #3 (hand washing sink)	0.039	0.005	0.015	Sink

Note: Regulatory limit for lead is 15 ppb or 0.015 mg/L; Regulatory limit for copper is 1300 ppb or 1.3 mg/L; BDL = below detectable limit; ppb = parts per billion; mg/l = milligrams per liter; NO = not operating; AU=Already used; WF = water fountain; L= lower; U=upper; CR=classroom; HW= hallway; BR=bathroom

The following options are recommended for the kitchen sink that failed on the first draw and fell within compliance on the second draw (following a 30-second flush):

- Flush the water system in the building and retest the sink/water fountain or
- Set up a "flushing" schedule, so that the sinks are flushed for >1 minute each morning prior to use (the process should be documented) or
- Replace faucet.

245 Albany Avenue • Thornwood • New York • 10594
 Tel (914) 439-6513 • Email: REGCOMP2@HOTMAIL.COM

Occupational

Safety

Environmental

COMPLIANCE IS SAFETY

If there are any questions or further information is required, please contact me at (914) 439-6513. Thank you for considering *RegCom* for your safety and compliance needs.

Sincerely,



Ernest C. Coon, MSc, RPIH, HEM

file: TUCK.1089.16.IH -cov.Rpt

245 Albany Avenue • Thornwood • New York • 10594
Tel (914) 439-6513 • Email: REGCOMP2@HOTMAIL.COM

Occupational

Safety


Environmental

COMPLIANCE IS SAFETY

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN Tuck-1089-16-1H - Tuckahoe UFSD - Cottle School

Date Collected: 07/22/2016
Collected By: Ernest Coon
Date Received: 07/22/2016
Date Analyzed: 07/27/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2439689	Teachers Lounge Sink	Water	0.013 mg/L
1B 2439690	Teachers Lounge Sink	Water	0.001 mg/L
2A 2439691	Nurses Office Sink	Water	0.003 mg/L
2B 2439692	Nurses Office Sink	Water	BDL < 0.001 mg/L
3A 2439693	Kitchen Hand Washing Sink	Water	0.039 mg/L
3B 2439694	Kitchen Hand Washing Sink	Water	0.005 mg/L
4A 2439695	Classroom 42 Water Fountain	Water	BDL < 0.001 mg/L
4B 2439696	Classroom 42 Water Fountain	Water	BDL < 0.001 mg/L
5 2439697	Not Applicable	Water Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits
Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095