


# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TUCK-1038-16-IH - Tuckahoe UFSD - HS/MS Building &amp; Cottle School

Date Collected: 04/09/2016  
Collected By: Ernest Coon  
Date Received: 04/09/2016  
Date Analyzed: 04/13/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2419006	Home & Careers Center Sink	Water	0.004 mg/L
1B 2419007	Home & Careers Center Sink	Water	BDL < 0.001 mg/L
2A 2419008	Kitchen Sink #1 (From Left to Right)	Water	0.005 mg/L
2B 2419009	Kitchen Sink #1 (From Left to Right)	Water	BDL < 0.001 mg/L
3A 2419010	Kitchen Sink #2 (From Left to Right)	Water	0.002 mg/L
3B 2419011	Kitchen Sink #2 (From Left to Right)	Water	0.001 mg/L
4B 2419012	Kitchen Sink #7 (From Left to Right)	Water	0.009 mg/L
5A 2419013	Hallway Water Fountain Near Room 308 - Elkay (Stainless Steel) Without Bottle Filler	Water	BDL < 0.001 mg/L
5B 2419014	Hallway Water Fountain Near Room 308 - Elkay (Stainless Steel) Without Bottle Filler	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TUCK-1038-16-IH - Tuckahoe UFSD - HS/MS Building &amp; Cottle School

Date Collected: 04/09/2016  
Collected By: Ernest Coon  
Date Received: 04/09/2016  
Date Analyzed: 04/13/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
6A 2419015	Hallway Water Fountain Near CR302 - Elkay (Stainless Steel) Without Bottle Filler	Water	BDL < 0.001 mg/L
6B 2419016	Hallway Water Fountain Near CR302 - Elkay (Stainless Steel) Without Bottle Filler	Water	0.001 mg/L
7A 2419017	Hallway Water Fountain Near CR206 - Elkay (Stainless Steel) Without Bottle Filler	Water	BDL < 0.001 mg/L
7B 2419018	Hallway Water Fountain Near CR206 - Elkay (Stainless Steel) Without Bottle Filler	Water	0.001 mg/L
8A 2419019	Hallway Water Fountain Near CR202B - Elkay (Stainless Steel) Without Bottle Filler	Water	0.001 mg/L
8B 2419020	Hallway Water Fountain Near CR202B - Elkay (Stainless Steel) Without Bottle Filler	Water	0.001 mg/L
9A 2419021	Hallway Water Fountain Near CR212 - Elkay (Stainless Steel) Without Bottle Filler	Water	0.001 mg/L
9B 2419022	Hallway Water Fountain Near CR212 - Elkay (Stainless Steel) Without Bottle Filler	Water	0.001 mg/L
10A 2419023	Hallway Water Fountain Near CR268 - Elkay (Stainless Steel) Without Bottle Filler	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TUCK-1038-16-IH - Tuckahoe UFSD - HS/MS Building & Cottle School

Date Collected: 04/09/2016  
Collected By: Ernest Coon  
Date Received: 04/09/2016  
Date Analyzed: 04/13/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10B 2419024	Hallway Water Fountain Near CR268 - Elkay (Stainless Steel) Without Bottle Filler	Water	0.001 mg/L
11A 2419025	Hallway Water Fountain Next to Gym (Upper Water Fountain) Stainless Steel	Water	BDL < 0.001 mg/L
11B 2419026	Hallway Water Fountain Next to Gym (Upper Water Fountain) Stainless Steel	Water	BDL < 0.001 mg/L
12A 2419027	Hallway Water Fountain Next to Gym (Lower Water Fountain) Stainless Steel	Water	0.004 mg/L
12B 2419028	Hallway Water Fountain Next to Gym (Lower Water Fountain) Stainless Steel	Water	BDL < 0.001 mg/L
13A 2419029	Hallway Water Fountain Bandwing (Stainless Steel Elkway Without Bottle Filler)	Water	0.001 mg/L
13B 2419030	Hallway Water Fountain Bandwing (Stainless Steel Elkway Without Bottle Filler)	Water	0.003 mg/L
14A 2419031	Hallway Water Fountain Near Guidance Office (Stainless Steel)	Water	BDL < 0.001 mg/L
14B 2419032	Hallway Water Fountain Near Guidance Office (Stainless Steel)	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TUCK-1038-16-IH - Tuckahoe UFSD - HS/MS Building & Cottle School

Date Collected: 04/09/2016  
Collected By: Ernest Coon  
Date Received: 04/09/2016  
Date Analyzed: 04/13/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
15A 2419033	Hallway Water Fountain Near Special Education Office - Stainless Steel Elkay Without Bottle Filler	Water	0.002 mg/L
15B 2419034	Hallway Water Fountain Near Special Education Office - Stainless Steel Elkay Without Bottle Filler	Water	0.003 mg/L
16A 2419035	Nurses' Office Bathroom Sink	Water	0.002 mg/L
16B 2419036	Nurses' Office Bathroom Sink	Water	BDL < 0.001 mg/L
17A 2419037	Teacher's Lounge Female Bathroom Sink	Water	0.001 mg/L
17B 2419038	Teacher's Lounge Female Bathroom Sink	Water	0.001 mg/L
18 2419039	Not Applicable	Water Blank	BDL < 0.001 mg/L
19A 2419040	CR42 Water Fountain Sink Combination	Water	0.196 mg/L
19B 2419041	CR42 Water Fountain Sink Combination	Water	0.004 mg/L

BDL = Below Detectable Limits  
Liability Limited to Cost of Analysis  
Results Applicable to Those Items Tested

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TUCK-1038-16-IH - Tuckahoe UFSD - HS/MS Building & Cottle School

Date Collected: 04/09/2016  
Collected By: Ernest Coon  
Date Received: 04/09/2016  
Date Analyzed: 04/13/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
20A 2419042	CR44 Water Fountain Sink Combination	Water	0.001 mg/L
20B 2419043	CR44 Water Fountain Sink Combination	Water	BDL < 0.001 mg/L
21A 2419044	CR39 Water Fountain Sink Combination	Water	0.001 mg/L
21B 2419045	CR39 Water Fountain Sink Combination	Water	0.001 mg/L
22A 2419046	Hallway Water Fountain Next to Room 39 (Stainless Steel)	Water	BDL < 0.001 mg/L
22B 2419047	Hallway Water Fountain Next to Room 39 (Stainless Steel)	Water	BDL < 0.001 mg/L
23A 2419048	Room 33 Girls Locker Room	Water	BDL < 0.001 mg/L
23B 2419049	Room 33 Girls Locker Room	Water	BDL < 0.001 mg/L
24A 2419050	Kitchen Sink #1 (From Left to Right)	Water	0.003 mg/L

BDL = Below Detectable Limits  
Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

ATHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TUCK-1038-16-IH - Tuckahoe UFSD - HS/MS Building &amp; Cottle School

Date Collected: 04/09/2016  
Collected By: Ernest Coon  
Date Received: 04/09/2016  
Date Analyzed: 04/13/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
24B 2419051	Kitchen Sink #1 (From Left to Right)	Water	0.001 mg/L
25A 2419052	Kitchen Sink #2 (From Left to Right)	Water	0.001 mg/L
25B 2419053	Kitchen Sink #2 (From Left to Right)	Water	0.001 mg/L
26A 2419054	Kitchen Sink #3 (From Left to Right)	Water	0.030 mg/L
26B 2419055	Kitchen Sink #3 (From Left to Right)	Water	0.003 mg/L
27A 2419056	CR21 Sink & Fountain Combination	Water	BDL < 0.001 mg/L
27B 2419057	CR21 Sink & Fountain Combination	Water	BDL < 0.001 mg/L
28A 2419058	Teacher's Lounge Sink	Water	0.021 mg/L
28B 2419059	Teacher's Lounge Sink	Water	0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN TUCK-1038-16-IH - Tuckahoe UFSD - HS/MS Building & Cottle School

Date Collected: 04/09/2016  
Collected By: Ernest Coon  
Date Received: 04/09/2016  
Date Analyzed: 04/13/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
29A 2419060	Hallway Water Fountain Near Teacher's Lounge - Stainless Steel (Upper)	Water	BDL < 0.001 mg/L
29B 2419061	Hallway Water Fountain Near Teacher's Lounge - Stainless Steel (Upper)	Water	BDL < 0.001 mg/L
30A 2419062	Hallway Water Fountain Near Teacher's Lounge - Stainless Steel (Lower)	Water	BDL < 0.001 mg/L
30B 2419063	Hallway Water Fountain Near Teacher's Lounge - Stainless Steel (Lower)	Water	BDL < 0.001 mg/L
31A 2419064	CR15 Sink & Water Fountain Combination	Water	0.001 mg/L
31B 2419065	CR15 Sink & Water Fountain Combination	Water	0.001 mg/L
32A 2419066	Hallway Water Fountain Near 4-1 - Stainless Steel	Water	BDL < 0.001 mg/L
32B 2419067	Hallway Water Fountain Near 4-1 - Stainless Steel	Water	0.001 mg/L
33 2419068	Not Applicable	Water Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095