



RegCom

Regulatory Compliance

Anthony Russo
Tuckahoe UFSD
65 Siwanoy Blvd
Eastchester, NY 10709

October 13, 2016

Dear Mr. Russo,

Please accept this letter as a report for the follow-up water testing report for the Tuckahoe UFSD. The investigation was completed on the 10/1/16.

Sinks that exceeded the NYS Action Level of 0.015 mg/L:

Sample #	Location	Lead Conc.(mg/L)
1	Cottle School - Hand washing Sink	0.062

Note: A possible remediation method, based upon the new NYS DOH regulation, Lead testing in School Drinking Water – 10 NYCRR Subpart 67-4 and the FAQs posted on the NYS DOH website, FAQ #16, it appears that school will meet compliance by simply posting a sign stating that the water should not be used for drinking or cooking. The FAQ #16 applies to sinks used for hand washing and cleaning.

For all outlets that exceed the NYS Action Level action is required. In accordance with the Lead testing in School Drinking Water – 10 NYCRR Subpart 67-4, if lead is detected the school is obligated to:

- Prohibit use of the outlet until a remediation plan is implemented and test results indicate that the lead levels are at or below the action level.
- Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed.
- Report the results to the local health department as soon as practicable but no more than 1 business day after the school received the laboratory report.
- Notify all staff and all persons in parental relation to students of the test results in writing as soon as practicable but no more than 10 business days after the school received the laboratory report.

245 Albany Avenue • Thornwood • New York • 10594
Tel (914) 439-6513 • Email: REGCOMP2@HOTMAIL.COM

Occupational

Safety

Environmental

COMPLIANCE IS SAFETY

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN TUCK-1125-16-IH - Tuckahoe - Cottle School

Date Collected: 10/01/2016

Collected By: S. Coon

Date Received: 10/04/2016

Date Analyzed: 10/11/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2457660	Kitchen Handwashing - Sink	Water	0.062 mg/L
2 2457661	Not Applicable	Water Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

- The school shall make available the results of all lead testing performed and remediation plans implemented on its website as soon as practicable, but no later than 6 weeks after the school received the laboratory results.

As a reminder:

- Schools that received lead testing results and implemented lead remediation plans prior to the effective date of these regulations, the school shall make available such information on the school's website as soon as practicable, but no more than 6 weeks after the effective date of these regulations.
- For results of tests performed before the effective date of these regulations, notify all staff and all persons in parental relation to students within 10 business days of this regulation's effective date, unless written notification has already occurred.
- As soon as practicable but no later than November 11, 2016 schools must report all testing results (whether above or below 15 ppb) to DOH, SED, local health department through the Department's designated statewide electronic reporting system.

Attached is the laboratory data sheet.

If there are any questions or further information is needed, please don't hesitate to contact me (914) 439-6513. Thank you for considering RegCom for your safety and compliance needs.

Sincerely,

Ernest C. Coon, MSc, RPIH, HEM

TUCK.1125.16.IH