

Pocantico Hills School

June 5, 2017
Annual Fire Inspection

Pocantico Hills School

Violation

- 02D-1 Rescue windows blocked in many classrooms.
- 12G-1 Electric closet 115 blocked electrical panels maintain 36" clearance
- 12I-1 Daisy chained extension cords in several areas – rooms 242, 211
- 12K-1 Open wires in electric room and junction box needs cover.
- 13B-2 Kitchen hood extinguisher system needs inspection.
- 14C-2 Corridor doors held open – Pre k suite. Tech room 218, and offices.
- 16A-2 Fire alarm has trouble indicated on panel.
- 17J-1 Remove desk in Middle school corridor area and all desks in halls.
- 23A-1 Emergency lights not working – Gym, Auditorium.