



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 08/16/16 13:45

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N038990-01	Lead	EPA 200.8	60.8	0.5	ug/L	15	ment Kitchen Triple Sink Left BK	8/11/16 08:15	8/22/16 15:28
N038990-02	Lead	EPA 200.8	16.7	0.5	ug/L	15	ent Kitchen Triple Sink Right BK	8/11/16 08:16	8/22/16 15:30
N038990-03	Lead	EPA 200.8	6.3	0.5	ug/L	15	sement Kitchen Single Sink BK1-	8/11/16 08:15	8/22/16 15:33
N038990-04	Lead	EPA 200.8	8.5	0.5	ug/L	15	sement Girls Single Sink BG-1-E	8/11/16 08:20	8/22/16 15:36
N038990-05	Lead	EPA 200.8	7.8	0.5	ug/L	15	sement Boys Single Sink BB-1-E	8/11/16 08:20	8/22/16 15:39
N038990-06	Lead	EPA 200.8	3.8	0.5	ug/L	15	lin Floor Boys Right Sink MFB-R-	8/11/16 08:25	8/22/16 15:41
N038990-07	Lead	EPA 200.8	11.1	0.5	ug/L	15	ain Floor Boys Left Sink MFB-L-E	8/11/16 08:25	8/22/16 15:44
N038990-08	Lead	EPA 200.8	5.2	0.5	ug/L	15	ain Floor Girls Left Sink MFG-R-E	8/11/16 08:30	8/23/16 12:33
N038990-09	Lead	EPA 200.8	2.7	0.5	ug/L	15	ain Floor Girls Right Sink MFG-L-	8/11/16 08:30	8/23/16 12:36
N038990-10	Lead	EPA 200.8	4.6	0.5	ug/L	15	Second Floor Kitchen Sink KC	8/11/16 08:35	8/23/16 12:39

New Jersey Analytical Laboratories

The
 cus.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved

Date Received: 09/29/16 15:00

Total Metals by EPA 200.8

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N040786-01	Lead	EPA 200.8	2.7	0.5	ug/L	15	BK3L Left Faucet 5 Min Flush	9/28/16 07:15	10/5/16 15:10
N040786-02	Lead	EPA 200.8	3.3	0.5	ug/L	15	BK3R Right Faucet 5 Min Flush	9/28/16 07:15	10/5/16 15:23
N040786-05	Lead	EPA 200.8	6.2	0.5	ug/L	15	WFLF Left WF 15 Min Flush	9/28/16 07:35	10/5/16 15:30
N040786-06	Lead	EPA 200.8	10.3	0.5	ug/L	15	WFRF Right WF 15 Min Flush	9/28/16 07:35	10/5/16 15:33
Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N040786-03	Lead	EPA 200.8	5.1	0.5	ug/L	15	WFL Left WF 1st Draw	9/28/16 07:20	10/5/16 15:25
N040786-04	Lead	EPA 200.8	6.8	0.5	ug/L	15	WFR Right WF 1st Draw	9/28/16 07:20	10/5/16 15:28

Susan McBrady