



The New York City Department of Education
Public School 34 K
Oliver Hazard Perry Elementary School
131 Norman Avenue
Brooklyn, New York 11222

Carmen Asselta
Principal
Maria LoRe Dioguardi
Assistant Principal

April 19, 2018


Dear Parent/Guardians,

As many of you know, there was an incident this morning in the building before the lineup. The construction company working on the boiler left a valve open. When the heating system was turned on, hot steam was released from the valve directly on to a fire sensor. This set off the fire alarms. Following safety procedures, the children and staff were evacuated and emergency services were called. Everyone was allowed back into the building when it was safe to do so. The safety of all the children, teachers and staff in our building is of utmost importance.

The rest of our school day will resume as normal.

I want to thank all of the teachers and staff for making sure the children were safe. If you have any questions or concerns please reach out to me at the school or Deise Kowalski our Parent Coordinator.

Sincerely,


Carmen Asselta
Principal