


**National Testing Laboratories, Ltd.**

556 South Mansfield Ypsilanti, MI 48197

Phone 734-483-8333 Fax 734-483-0340

(E-mail) cmacmillan@NTLLABS.com



March 16, 2017

**PROJECT COVER SHEET**

School: Carlstadt Public Schools: 550 Washington St: Carlstadt, NJ 07072

Order number: 2089893

NTL Sample number(s): 745406 - 745452

Client name: LEW Corp  
1090 Bristol Rd  
Mountainside, NJ 07092

Analysis Type: Lead, EPA Method 200.8 and/or Standard Method 3113B

Results, Discussion, Qualifiers:

745410 Metals sample required digestion. Sample digested on 03/03/2017.

745449 Metals sample required digestion. Sample digested on 03/03/2017.

*Christine MacMillan*

National Testing Laboratories, Ltd.  
Laboratory Director

**Corporate Headquarters**

6571 Wilson Mills Rd.

Cleveland, Ohio 44143

Phone 440-449-2525 Fax 440-449-8585

Toll free 800-458-3330

Website: [www.ntllabs.com](http://www.ntllabs.com)

Laboratory Certification #: MI859



Quality Water Analysis

556 South Mansfield Street  
Ypsilanti, MI 48197  
1-800-604-1995

Lead Only

Analysis Report

Sample #	Sample ID	Method	Parameter	Level Detected	EPA Standards	Units	LRL	Date Sampled	Date Analyzed
745427	C-DW 1st Flr Hall	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745428	C-DW Rm 156	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745429	C-DW Rm 155	3113B	Lead	1	15	ug/L	1	02/23/2017	03/03/2017
745430	C-DW Rm 147	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745431	C-DW Rm 154	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745432	C-DW Rm 153	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745433	C-DW Rm 148	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745434	C-DW Rm 152	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745435	C-DW Rm 149	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745436	C-DW Rm 150	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745437	C-DW Rm 202	3113B	Lead	2	15	ug/L	1	02/23/2017	03/03/2017
745438	C-DW Rm 203	3113B	Lead	2	15	ug/L	1	02/23/2017	03/03/2017
745439	C-WC 2nd Flr Hall	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745440	C-DW Rm 238	3113B	Lead	4	15	ug/L	1	02/23/2017	03/03/2017
745441	C-DW Rm 237	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745442	C-DW Rm 227	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745443	C-DW Rm 236	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745444	C-DW Rm 235	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745445	C-DW Rm 228	3113B	Lead	6	15	ug/L	1	02/23/2017	03/03/2017
745446	C-DW Rm 234	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745447	C-DW Rm 229	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745448	C-DW Rm 230	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745449	C-S Rm 209	200.8	Lead	6	15	ug/L	1	02/23/2017	03/04/2017
745450	C-DW Rm 302	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745451	C-WC 3rd Flr hall	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017
745452	ASTM Blank lot 2607739	3113B	Lead	ND	15	ug/L	1	02/23/2017	03/03/2017

Analyst	Tests
DD	3113B
JP	200.8

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as Eastern Time.

Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc. were provided by the client. This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, LTD.

Laboratory Certification #: MI859

 **National Testing  
Laboratories, Ltd.**

*Quality Water Analysis*

556 South Mansfield Street  
Ypsilanti, MI 48197  
1-800-604-1995

**Lead Only**

## **Analysis Report**

**Legend:**

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL).  
"NA" Not analyzed.  
"EPA Standard" This column indicates the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.  
"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.  
"PIA" Presence/Absence

**Reviewed by Authorized Signatory**

---

Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc. were provided by the client. This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, LTD.